

Report No.:

Test Time: 2018/8/28 15:37

Luminaire Property

Luminaire Manufacturer:

Luminaire Category: RIBBONLYTE

Luminaire Description: RBS2241.524PH 1FT(300mm)

Luminous Length (mm): 300

Luminous Width (mm): 8

Luminous Height (mm): 1

Voltage: 24.0 V

Current: 0.061 A

Power: 1.47 W

Power Factor: 1.000

Photometric Results

CIE Class: Direct

Measurement Flux: 165.3 lm

Downward Ratio: 99%

Horizontal Diffuse Angle(50%): H115.6

Vertical Diffuse Angle(50%): V115.6

Luminaire Efficacy Rating (LER): 112

Max. Intensity: 55.82 cd

Total Rated Lamp Lumens: 165.3 lm


Efficiency: 100%

Upward Ratio: 1%


Central Intensity: 55.65 cd

Pos of Max. Intensity: H150 V1

Picture Of Luminaire



Luminous Intensity Distribution Curve



Average Diffuse Angle(50%): 115.6° Unit: cd

— C0-C180 — C90-C270

C Plane (°):0.0-360.0: 30.0

Test Lab:

Test Type: TYPE C

Temperature: 25

Operator: Aaron

Gamma Plane (°):0.0-180.0: 1.0



Test Device: GPM-1800B

Distance: 9.028 m

Humidity: 60%

Inspector:


Luminous Intensity Distribution Curve



C Plane (°):0.0-360.0: 30.0
Test Lab:
Test Type: TYPE C
Temperature: 25
Operator: Aaron

Gamma Plane (°):0.0-180.0:1.0
Test Device: GPM-1800B
Distance: 9.028 m
Humidity: 60%
Inspector:

Luminous Intensity Distribution Curve(cd/klm)



C Plane (°):0.0-360.0: 30.0
Test Lab:
Test Type: TYPE C
Temperature: 25
Operator: Aaron

Gamma Plane (°):0.0-180.0:1.0
Test Device: GPM-1800B
Distance: 9.028 m
Humidity: 60%
Inspector:


Coefficients Of Utilization - Zonal Cavity Method

RC	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.5	0.5	0.5	0.3	0.3	0.3	0.1	0.1	0.1	0
RW	0.7	0.5	0.3	0.1	0.7	0.5	0.3	0.1	0.5	0.3	0.1	0.5	0.3	0.1	0.5	0.3	0.1	0
RCR	RF = 0.2																	
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	101	101	101	99
1	108	104	99	95	106	101	97	94	97	94	91	93	90	88	89	87	85	83
2	98	90	83	77	96	88	82	76	84	79	74	81	77	73	78	74	71	69
3	90	79	71	64	87	77	70	63	74	68	62	71	66	61	69	64	60	58
4	82	70	61	54	80	68	60	54	66	59	53	63	57	52	61	56	51	49
5	75	62	53	46	73	61	53	46	59	51	46	57	50	45	55	49	44	42
6	69	56	47	40	67	55	46	40	53	45	40	51	45	39	50	44	39	37
7	64	51	42	36	63	50	41	35	48	41	35	47	40	35	45	39	35	32
8	60	46	38	32	58	45	37	32	44	37	31	43	36	31	42	35	31	29
9	56	42	34	28	54	42	34	28	41	33	28	39	33	28	38	32	28	26
10	52	39	31	26	51	39	31	26	37	30	26	36	30	25	36	30	25	23

Spacing Criteria (0-180): 1.28

Spacing Criteria (90-270): 1.27

Spacing Criteria (Diagonal): 1.40



C Plane (°):0.0-360.0: 30.0

Test Lab:

Test Type: TYPE C

Temperature: 25

Operator: Aaron

Gamma Plane (°):0.0-180.0:1.0


Test Device: GPM-1800B

Distance: 9.028 m

Humidity: 60%

Inspector:

Isocandela (rectangle)



Imax (100%): 56 cd

(10%):	6 cd	(20%):	11 cd
(25%):	14 cd	(30%):	17 cd
(40%):	22 cd	(50%):	28 cd
(60%):	33 cd	(70%):	39 cd
(80%):	45 cd	(90%):	50 cd

C Plane (°):0.0-360.0: 30.0

Test Lab:

Test Type: TYPE C

Temperature: 25

Operator: Aaron

Gamma Plane (°):0.0-180.0:1.0


Test Device: GPM-1800B

Distance: 9.028 m

Humidity: 60%

Inspector:

IsoLux Plot



C Plane (°):0.0-360.0: 30.0

Test Lab:

Test Type: TYPE C

Temperature: 25

Operator: Aaron

Gamma Plane (°):0.0-180.0:1.0

Test Device: GPM-1800B

Distance: 9.028 m



Humidity: 60%

Inspector:

Lum Limit Curve

Dazzle	Quality	Illuminance (lx)							
1.15	A	2000	1000	500	<=300				
1.50	B		2000	1000	500	<=300			
1.85	C			2000	1000	500	<=300		
2.20	D				2000	1000	500	<=300	
2.55	E					2000	1000	500	<=300

a b c d e f g h



L(cd/sq.m)	G45	G50	G55	G60	G65	G70	G75	G80	G85
C0	20265	19628	18899	17927	16677	14854	12580	9520	5236
C90	22623	22436	22066	21609	20890	19689	17984	14224	3776
C180	19940	19306	18517	17502	16257	14509	12141	9056	4941
C270	22447	22236	21842	21261	20518	19460	17650	14648	5895

C Plane (°):0.0-360.0: 30.0

Test Lab:

Test Type: TYPE C

Temperature: 25

Operator: Aaron

Gamma Plane (°):0.0-180.0:1.0


Test Device: GPM-1800B

Distance: 9.028 m

Humidity: 60%

Inspector:

Illuminance at a Distance



C Plane (°):0.0-360.0: 30.0

Test Lab:

Test Type: TYPE C

Temperature: 25

Operator: Aaron

Gamma Plane (°):0.0-180.0:1.0


Test Device: GPM-1800B

Distance: 9.028 m

Humidity: 60%

Inspector:

Vertical IsoLux Plot



Lowest(m): 2.0m	Highest(m): 5.0m	Max Lux: 13.9 lx
(10%): 1.4 lx	(20%): 2.8 lx	
(25%): 3.5 lx	(30%): 4.2 lx	
(40%): 5.6 lx	(50%): 7.0 lx	
(60%): 8.3 lx	(70%): 9.7 lx	
(80%): 11.1 lx	(90%): 12.5 lx	

C Plane (°):0.0-360.0: 30.0

Test Lab:

Test Type: TYPE C

Temperature: 25

Operator: Aaron

Gamma Plane (°):0.0-180.0:1.0

Test Device: GPM-1800B

Distance: 9.028 m

Humidity: 60%

Inspector:

Area Flux Table

Unit: lm

		Vertical plane																		Flux(T)		Flux(E)	
		-90	-80	-70	-60	-50	-40	-30	-20	-10	0	10	20	30	40	50	60	70	80				
Horizontal plane	Flux(T)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	164		
	Flux(E)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		162	
	0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0			
	10	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0			
	20	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0			
	30	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0			
	40	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0			
	50	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0			
	60	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0			
	70	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0			
80	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0				
90	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0				
Flux(T)	0.1	1.0	2.9	5.7	8.9	12.3	15.2	17.4	18.5	18.5	17.4	15.3	12.3	9.0	5.8	2.9	1.0	0.1	164				
Flux(E)	0.0	0.8	2.7	5.5	8.8	12.1	15.1	17.2	18.4	18.4	17.3	15.1	12.2	8.9	5.6	2.8	0.8	0.0		162			

C Plane (°):0.0-360.0: 30.0

Test Lab:

Test Type: TYPE C

Temperature: 25

Operator: Aaron

Gamma Plane (°):0.0-180.0:1.0


Test Device: GPM-1800B

Distance: 9.028 m

Humidity: 60%

Inspector:

The Average Illuminance Effective Figure



UGR Table

Reflectance:										
Ceiling (cavity)	0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall	0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions	Viewed crosswise					Viewed endwise				
X=2H Y=2H	29.0	30.7	29.4	31.0	31.3	28.6	30.3	29.0	30.6	30.9
3H	30.9	32.3	31.3	32.7	33.1	30.3	31.8	30.7	32.2	32.5
4H	31.5	32.9	32.0	33.3	33.7	30.9	32.3	31.3	32.7	33.1
6H	32.0	33.3	32.4	33.7	34.1	31.3	32.6	31.7	33.0	33.4
8H	32.2	33.4	32.6	33.8	34.2	31.3	32.6	31.8	33.0	33.4
12H	32.3	33.4	32.7	33.8	34.3	31.3	32.5	31.8	32.9	33.4
X=4H Y=2H	29.6	31.0	30.0	31.3	31.7	29.3	30.7	29.7	31.0	31.4
3H	31.6	32.8	32.0	33.2	33.6	31.2	32.4	31.6	32.8	33.2
4H	32.4	33.5	32.9	33.9	34.4	31.9	33.0	32.3	33.4	33.8
6H	33.0	33.9	33.5	34.4	34.9	32.4	33.3	32.8	33.7	34.2
8H	33.2	34.1	33.7	34.5	35.0	32.4	33.3	32.9	33.8	34.2
12H	33.3	34.1	33.8	34.6	35.1	32.5	33.2	32.9	33.7	34.2
X=8H Y=4H	32.7	33.5	33.1	34.0	34.5	32.2	33.1	32.7	33.5	34.0
6H	33.3	34.1	33.9	34.6	35.1	32.7	33.5	33.3	34.0	34.5
8H	33.6	34.2	34.1	34.7	35.2	32.9	33.5	33.4	34.0	34.5
12H	33.8	34.3	34.3	34.8	35.4	32.9	33.5	33.4	34.0	34.6
X=12H Y=4H	32.7	33.5	33.2	33.9	34.4	32.2	33.0	32.7	33.5	34.0
6H	33.4	34.0	33.9	34.5	35.1	32.8	33.5	33.3	33.9	34.5
8H	33.7	34.2	34.2	34.7	35.3	33.0	33.5	33.5	34.0	34.6

Calculate in accordance with CIE 190:2010

C Plane (°):0.0-360.0: 30.0

Test Lab:

Test Type: TYPE C

Temperature: 25

Operator: Aaron

Gamma Plane (°):0.0-180.0: 1.0

Test Device: GPM-1800B

Distance: 9.028 m

Humidity: 60%

Inspector:

Utilisation Factor Table(Floor cavity)

Utilisation Factors UF(F)			SHR NOM = 1.25								
Room Reflectance			Room Index(RI)								
Ceiling	Wall	Floor	0.75	1.00	1.25	1.50	2.00	2.50	3.00	4.00	5.00
0.70	0.50	0.20	0.56	0.66	0.74	0.79	0.86	0.92	0.95	1.00	1.03
	0.30		0.48	0.58	0.66	0.72	0.80	0.86	0.90	0.96	0.99
	0.20		0.42	0.52	0.60	0.66	0.75	0.81	0.86	0.92	0.96
0.50	0.50	0.20	0.54	0.64	0.71	0.76	0.83	0.88	0.91	0.96	0.99
	0.30		0.47	0.57	0.64	0.70	0.78	0.83	0.87	0.92	0.96
	0.20		0.41	0.52	0.59	0.65	0.73	0.79	0.83	0.89	0.93
0.30	0.50	0.20	0.52	0.62	0.69	0.73	0.80	0.85	0.88	0.92	0.95
	0.30		0.46	0.56	0.63	0.68	0.76	0.81	0.84	0.89	0.92
	0.20		0.41	0.51	0.58	0.64	0.72	0.77	0.81	0.87	0.90
0.00	0.00	0.00	0.39	0.49	0.56	0.61	0.68	0.73	0.77	0.82	0.85
<p>Rating: 1W Photometrically tested without ceiling board.</p> <p>Multiply UF values by service correction factors</p> <p>Calculate in accordance with CIBSE Technical Memorandum NO.5 1980</p>											

Utilisation Factor Table(Wall)

Utilisation Factors UF(W)			SHR NOM = 1.25								
Room Reflectance			Room Index(RI)								
Ceiling	Wall	Floor	0.75	1.00	1.25	1.50	2.00	2.50	3.00	4.00	5.00
0.70	0.50	0.20	1.01	0.84	0.71	0.62	0.49	0.41	0.35	0.27	0.22
	0.30		0.84	0.72	0.62	0.55	0.45	0.38	0.32	0.26	0.21
	0.20		0.72	0.62	0.55	0.49	0.41	0.35	0.30	0.24	0.20
0.50	0.50	0.20	0.98	0.80	0.68	0.59	0.47	0.42	0.33	0.26	0.21
	0.30		0.83	0.70	0.60	0.53	0.43	0.36	0.31	0.24	0.20
	0.20		0.72	0.62	0.54	0.48	0.40	0.34	0.29	0.23	0.19
0.30	0.50	0.20	0.95	0.77	0.66	0.57	0.45	0.37	0.32	0.25	0.20
	0.30		0.81	0.68	0.59	0.52	0.42	0.35	0.30	0.24	0.19
	0.20		0.71	0.61	0.53	0.47	0.39	0.33	0.28	0.22	0.19
0.00	0.00	0.00	0.61	0.51	0.44	0.39	0.31	0.26	0.22	0.18	0.14
<p>Rating: 1W Photometrically tested without ceiling board.</p> <p>Multiply UF values by service correction factors</p> <p>Calculate in accordance with CIBSE Technical Memorandum NO.5 1980</p>											

Utilisation Factor Table(Ceiling cavity)

Utilisation Factors UF(C)			SHR NOM = 1.25								
Room Reflectance			Room Index(RI)								
Ceiling	Wall	Floor	0.75	1.00	1.25	1.50	2.00	2.50	3.00	4.00	5.00
0.70	0.50	0.20	0.17	0.18	0.19	0.20	0.21	0.21	0.22	0.22	0.22
	0.30		0.10	0.12	0.13	0.14	0.16	0.17	0.18	0.19	0.20
	0.20		0.05	0.07	0.08	0.10	0.12	0.13	0.14	0.16	0.17
0.50	0.50	0.20	0.16	0.18	0.18	0.19	0.20	0.20	0.21	0.21	0.21
	0.30		0.10	0.11	0.13	0.14	0.15	0.16	0.17	0.18	0.19
	0.20		0.05	0.07	0.08	0.09	0.11	0.13	0.14	0.16	0.17
0.30	0.50	0.20	0.16	0.17	0.18	0.18	0.19	0.20	0.20	0.20	0.21
	0.30		0.10	0.11	0.12	0.13	0.15	0.16	0.17	0.18	0.18
	0.20		0.05	0.07	0.08	0.09	0.11	0.13	0.14	0.15	0.16
0.00	0.00	0.00	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01
<p>Rating: 1W Photometrically tested without ceiling board.</p> <p>Multiply UF values by service correction factors</p> <p>Calculate in accordance with CIBSE Technical Memorandum NO.5 1980</p>											