

Report No.:

Test Time: 2018/8/28 17:44

Luminaire Property

Luminaire Manufacturer:

Luminaire Category: RIBBONLYTE

Luminaire Description: RBS2241.540PH 1FT(300mm)

Luminous Length (mm): 300

Luminous Width (mm): 8

Luminous Height (mm): 1

Voltage: 24.0 V

Current: 0.060 A

Power: 1.44 W

Power Factor: 1.000

Photometric Results

CIE Class: Direct

Measurement Flux: 194 lm

Downward Ratio: 99%

Horizontal Diffuse Angle(50%): H117.9

Vertical Diffuse Angle(50%): V117.7

Luminaire Efficacy Rating (LER): 135

Max. Intensity: 63.98 cd

Total Rated Lamp Lumens: 194.0 lm


Efficiency: 100%

Upward Ratio: 1%


Central Intensity: 63.92 cd

Pos of Max. Intensity: H120 V0

Picture Of Luminaire



Luminous Intensity Distribution Curve



Average Diffuse Angle(50%): 117.8° Unit: cd

— C0-C180 — C90-C270

C Plane (°):0.0-360.0: 30.0

Test Lab:

Test Type: TYPE C

Temperature: 25

Operator: Aaron

Gamma Plane (°):0.0-180.0:1.0



Test Device: GPM-1800B

Distance: 9.028 m

Humidity: 60%

Inspector:


Luminous Intensity Distribution Curve



C Plane (°):0.0-360.0: 30.0
Test Lab:
Test Type: TYPE C
Temperature: 25
Operator: Aaron

Gamma Plane (°):0.0-180.0:1.0
Test Device: GPM-1800B
Distance: 9.028 m
Humidity: 60%
Inspector:

Luminous Intensity Distribution Curve(cd/klm)



C Plane (°):0.0-360.0: 30.0
Test Lab:
Test Type: TYPE C
Temperature: 25
Operator: Aaron

Gamma Plane (°):0.0-180.0:1.0
Test Device: GPM-1800B
Distance: 9.028 m
Humidity: 60%
Inspector:


Coefficients Of Utilization - Zonal Cavity Method

RC	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.5	0.5	0.5	0.3	0.3	0.3	0.1	0.1	0.1	0
RW	0.7	0.5	0.3	0.1	0.7	0.5	0.3	0.1	0.5	0.3	0.1	0.5	0.3	0.1	0.5	0.3	0.1	0
RCR	RF = 0.2																	
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	101	101	101	99
1	108	104	99	95	106	101	97	94	97	94	91	93	90	88	89	87	85	83
2	98	90	83	77	96	88	82	76	84	79	74	81	76	72	78	74	71	68
3	89	79	70	64	87	77	69	63	74	67	62	71	65	61	68	64	60	57
4	82	70	61	54	79	68	60	53	66	58	52	63	57	52	61	55	51	49
5	75	62	53	46	73	61	52	46	59	51	45	57	50	45	55	49	44	42
6	69	56	47	40	67	55	46	40	53	45	39	51	44	39	49	43	39	36
7	64	50	41	35	62	50	41	35	48	40	35	46	40	34	45	39	34	32
8	60	46	37	31	58	45	37	31	44	36	31	42	36	31	41	35	31	29
9	56	42	34	28	54	41	33	28	40	33	28	39	32	28	38	32	27	26
10	52	39	31	25	51	38	31	25	37	30	25	36	30	25	35	29	25	23

Spacing Criteria (0-180): 1.29

Spacing Criteria (90-270): 1.29

Spacing Criteria (Diagonal): 1.41



C Plane (°):0.0-360.0: 30.0

Test Lab:

Test Type: TYPE C

Temperature: 25

Operator: Aaron

Gamma Plane (°):0.0-180.0:1.0


Test Device: GPM-1800B

Distance: 9.028 m

Humidity: 60%

Inspector:

Isocandela (rectangle)



Imax (100%): 64 cd

(10%):	6 cd	(20%):	13 cd
(25%):	16 cd	(30%):	19 cd
(40%):	26 cd	(50%):	32 cd
(60%):	38 cd	(70%):	45 cd
(80%):	51 cd	(90%):	58 cd

C Plane (°):0.0-360.0: 30.0

Test Lab:

Test Type: TYPE C

Temperature: 25

Operator: Aaron

Gamma Plane (°):0.0-180.0:1.0


Test Device: GPM-1800B

Distance: 9.028 m

Humidity: 60%

Inspector:

IsoLux Plot



Mounting Height: 5.0m Max Lux(100%): 2.6 lx

(10%): 0.3 lx	(20%): 0.5 lx
(25%): 0.6 lx	(30%): 0.8 lx
(40%): 1.0 lx	(50%): 1.3 lx
(60%): 1.5 lx	(70%): 1.8 lx
(80%): 2.0 lx	(90%): 2.3 lx

C Plane (°):0.0-360.0: 30.0

Test Lab:

Test Type: TYPE C

Temperature: 25

Operator: Aaron

Gamma Plane (°):0.0-180.0:1.0

Test Device: GPM-1800B

Distance: 9.028 m



Humidity: 60%

Inspector:

Lum Limit Curve

Dazzle	Quality	Illuminance (lx)							
1.15	A	2000	1000	500	<=300				
1.50	B		2000	1000	500	<=300			
1.85	C			2000	1000	500	<=300		
2.20	D				2000	1000	500	<=300	
2.55	E					2000	1000	500	<=300

a b c d e f g h



L(cd/sq.m)	G45	G50	G55	G60	G65	G70	G75	G80	G85
C0	23649	23018	22221	21126	19601	17610	14776	11064	5885
C90	26563	26362	26129	25610	24806	23552	21768	16014	3914
C180	23586	22956	22166	21126	19671	17710	14809	11064	6240
C270	26387	26188	25847	25287	24542	23202	21148	18039	6217

C Plane (°):0.0-360.0: 30.0

Test Lab:

Test Type: TYPE C

Temperature: 25

Operator: Aaron

Gamma Plane (°):0.0-180.0:1.0


Test Device: GPM-1800B

Distance: 9.028 m

Humidity: 60%

Inspector:

Illuminance at a Distance



C Plane (°):0.0-360.0: 30.0

Test Lab:

Test Type: TYPE C

Temperature: 25

Operator: Aaron

Gamma Plane (°):0.0-180.0:1.0


Test Device: GPM-1800B

Distance: 9.028 m

Humidity: 60%

Inspector:

Vertical IsoLux Plot



Lowest(m): 2.0m	Highest(m): 5.0m	Max Lux: 16.0 lx
(10%): 1.6 lx	(20%): 3.2 lx	
(25%): 4.0 lx	(30%): 4.8 lx	
(40%): 6.4 lx	(50%): 8.0 lx	
(60%): 9.6 lx	(70%): 11.2 lx	
(80%): 12.8 lx	(90%): 14.4 lx	

C Plane (°):0.0-360.0: 30.0

Test Lab:

Test Type: TYPE C

Temperature: 25

Operator: Aaron

Gamma Plane (°):0.0-180.0:1.0

Test Device: GPM-1800B

Distance: 9.028 m


Humidity: 60%

Inspector:

Unit: 1m

Gamma Plane (°):0.0-180.0:1.0
Test Device: GPM-1800B
Distance: 9.028 m
Humidity: 60%
Inspector:

The Average Illuminance Effective Figure



C Plane (°):0.0-360.0: 30.0
 Test Lab:
 Test Type: TYPE C
 Temperature: 25
 Operator: Aaron

Gamma Plane (°):0.0-180.0:1.0
 Test Device: GPM-1800B
 Distance: 9.028 m
 Humidity: 60%
 Inspector:

UGR Table

Reflectance:										
Ceiling (cavity)	0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall	0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions	Viewed crosswise					Viewed endwise				
X=2H Y=2H	29.0	30.7	29.4	31.0	31.3	28.7	30.3	29.1	30.7	31.0
3H	30.9	32.4	31.3	32.7	33.1	30.4	31.9	30.8	32.2	32.6
4H	31.6	33.0	32.0	33.3	33.7	31.0	32.4	31.4	32.8	33.2
6H	32.1	33.4	32.5	33.7	34.1	31.4	32.7	31.8	33.0	33.4
8H	32.2	33.4	32.6	33.8	34.2	31.4	32.6	31.8	33.0	33.5
12H	32.3	33.5	32.7	33.9	34.3	31.4	32.6	31.8	33.0	33.4
X=4H Y=2H	29.6	31.0	30.0	31.4	31.8	29.4	30.8	29.8	31.1	31.5
3H	31.7	32.9	32.1	33.3	33.7	31.3	32.5	31.7	32.9	33.3
4H	32.5	33.5	32.9	34.0	34.4	32.0	33.1	32.4	33.5	33.9
6H	33.1	34.0	33.5	34.4	34.9	32.4	33.4	32.9	33.8	34.3
8H	33.2	34.1	33.7	34.6	35.0	32.5	33.4	33.0	33.8	34.3
12H	33.3	34.1	33.8	34.6	35.1	32.5	33.3	33.0	33.8	34.3
X=8H Y=4H	32.7	33.6	33.2	34.0	34.5	32.3	33.2	32.8	33.6	34.1
6H	33.4	34.1	33.9	34.6	35.1	32.8	33.6	33.3	34.1	34.5
8H	33.6	34.3	34.1	34.8	35.3	33.0	33.6	33.5	34.1	34.6
12H	33.8	34.4	34.3	34.9	35.4	33.0	33.6	33.5	34.1	34.6
X=12H Y=4H	32.7	33.5	33.2	34.0	34.5	32.3	33.1	32.8	33.6	34.1
6H	33.4	34.1	33.9	34.5	35.1	32.9	33.5	33.4	34.0	34.6
8H	33.7	34.3	34.2	34.8	35.3	33.0	33.6	33.6	34.1	34.7

Calculate in accordance with CIE 190:2010

C Plane (°):0.0-360.0: 30.0
 Test Lab:
 Test Type: TYPE C
 Temperature: 25
 Operator: Aaron

Gamma Plane (°):0.0-180.0:1.0
 Test Device: GPM-1800B
 Distance: 9.028 m
 Humidity: 60%
 Inspector:

Utilisation Factor Table(Floor cavity)

Utilisation Factors UF(F)			SHR NOM = 1.50									
Room Reflectance			Room Index(RI)									
Ceiling	Wall	Floor	0.75	1.00	1.25	1.50	2.00	2.50	3.00	4.00	5.00	
0.70	0.50	0.20	0.59	0.67	0.75	0.80	0.87	0.92	0.96	1.00	1.03	
	0.30		0.51	0.60	0.68	0.73	0.81	0.87	0.91	0.96	1.00	
	0.20		0.46	0.54	0.62	0.68	0.76	0.82	0.87	0.93	0.97	
0.50	0.50	0.20	0.57	0.65	0.72	0.77	0.84	0.89	0.92	0.96	0.99	
	0.30		0.50	0.58	0.66	0.71	0.79	0.84	0.88	0.93	0.96	
	0.20		0.45	0.53	0.61	0.67	0.75	0.80	0.84	0.90	0.94	
0.30	0.50	0.20	0.56	0.63	0.70	0.75	0.81	0.85	0.89	0.92	0.95	
	0.30		0.50	0.57	0.65	0.70	0.77	0.82	0.85	0.90	0.93	
	0.20		0.45	0.53	0.60	0.66	0.73	0.78	0.82	0.87	0.91	
0.00	0.00	0.00	0.43	0.50	0.57	0.62	0.70	0.74	0.78	0.83	0.86	
Rating:1W Photometrically tested without ceiling board. Multiply UF values by service correction factors Calculate in accordance with CIBSE Technical Memorandum NO.5 1980												

C Plane (°):0.0-360.0: 30.0

Test Lab:

Test Type: TYPE C

Temperature: 25

Operator: Aaron

Gamma Plane (°):0.0-180.0:1.0

Test Device: GPM-1800B

Distance: 9.028 m

Humidity: 60%

Inspector:

Utilisation Factor Table(Wall)

Utilisation Factors UF(W)			SHR NOM = 1.50									
Room Reflectance			Room Index(RI)									
Ceiling	Wall	Floor	0.75	1.00	1.25	1.50	2.00	2.50	3.00	4.00	5.00	
0.70	0.50	0.20	0.96	0.82	0.69	0.60	0.48	0.40	0.34	0.26	0.21	
	0.30		0.80	0.70	0.60	0.53	0.43	0.37	0.32	0.25	0.20	
	0.20		0.69	0.61	0.53	0.48	0.40	0.34	0.29	0.23	0.19	
0.50	0.50	0.20	0.93	0.79	0.66	0.58	0.46	0.41	0.32	0.25	0.20	
	0.30		0.78	0.68	0.58	0.52	0.42	0.35	0.30	0.24	0.20	
	0.20		0.68	0.60	0.52	0.47	0.39	0.33	0.29	0.23	0.19	
0.30	0.50	0.20	0.90	0.75	0.64	0.55	0.44	0.36	0.31	0.24	0.19	
	0.30		0.77	0.66	0.57	0.50	0.40	0.34	0.29	0.23	0.19	
	0.20		0.67	0.59	0.51	0.46	0.38	0.32	0.28	0.22	0.18	
0.00	0.00	0.00	0.57	0.50	0.42	0.37	0.30	0.25	0.22	0.17	0.14	
Rating:1W Photometrically tested without ceiling board. Multiply UF values by service correction factors Calculate in accordance with CIBSE Technical Memorandum NO.5 1980												

C Plane (°):0.0-360.0: 30.0

Test Lab:

Test Type: TYPE C

Temperature: 25

Operator: Aaron

Gamma Plane (°):0.0-180.0:1.0

Test Device: GPM-1800B

Distance: 9.028 m

Humidity: 60%

Inspector:

Utilisation Factor Table(Ceiling cavity)

Utilisation Factors UF(C)			SHR NOM = 1.50									
Room Reflectance			Room Index(RI)									
Ceiling	Wall	Floor	0.75	1.00	1.25	1.50	2.00	2.50	3.00	4.00	5.00	
0.70	0.50	0.20	0.17	0.18	0.19	0.20	0.20	0.21	0.21	0.22	0.22	
	0.30		0.10	0.12	0.13	0.14	0.16	0.17	0.18	0.19	0.20	
	0.20		0.05	0.07	0.08	0.10	0.12	0.13	0.14	0.16	0.17	
0.50	0.50	0.20	0.16	0.17	0.18	0.19	0.20	0.20	0.21	0.21	0.21	
	0.30		0.10	0.11	0.13	0.14	0.15	0.16	0.17	0.18	0.19	
	0.20		0.05	0.07	0.08	0.10	0.11	0.13	0.14	0.16	0.17	
0.30	0.50	0.20	0.16	0.17	0.18	0.18	0.19	0.19	0.20	0.20	0.20	
	0.30		0.10	0.11	0.12	0.13	0.15	0.16	0.17	0.18	0.18	
	0.20		0.05	0.07	0.08	0.09	0.11	0.13	0.14	0.15	0.16	
0.00	0.00	0.00	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	
Rating:1W Photometrically tested without ceiling board. Multiply UF values by service correction factors Calculate in accordance with CIBSE Technical Memorandum NO.5 1980												