

Report No.:

Test Time: 2018/8/29 16:35

Luminaire Property

Luminaire Manufacturer:

Luminaire Category: RIBBONLYTE

Luminaire Description: RBS2242.260PH 1FT(300mm)

Luminous Length (mm): 300

Luminous Width (mm): 8

Luminous Height (mm): 1

Voltage: 24.0 V

Current: 0.087 A

Power: 2.08 W

Power Factor: 1.000

Photometric Results

CIE Class: Direct

Measurement Flux: 269.3 lm

Downward Ratio: 99%

Horizontal Diffuse Angle(50%): H118.9

Vertical Diffuse Angle(50%): V118.9

Luminaire Efficacy Rating (LER): 129

Max. Intensity: 87.74 cd

Total Rated Lamp Lumens: 269.3 lm


Efficiency: 100%

Upward Ratio: 1%


Central Intensity: 87.25 cd

Pos of Max. Intensity: H300 V2

Picture Of Luminaire



Luminous Intensity Distribution Curve



Average Diffuse Angle(50%): 118.9° Unit: cd

— C0-C180 — C90-C270

C Plane (°):0.0-360.0: 30.0

Test Lab:

Test Type: TYPE C

Temperature: 25

Operator: Aaron

Gamma Plane (°):0.0-180.0:1.0


Test Device: GPM-1800B

Distance: 9.028 m

Humidity: 60%

Inspector:


Luminous Intensity Distribution Curve



C Plane (°):0.0-360.0: 30.0
Test Lab:
Test Type: TYPE C
Temperature: 25
Operator: Aaron

Gamma Plane (°):0.0-180.0:1.0
Test Device: GPM-1800B
Distance: 9.028 m
Humidity: 60%
Inspector:

Luminous Intensity Distribution Curve(cd/klm)



C Plane (°):0.0-360.0: 30.0
Test Lab:
Test Type: TYPE C
Temperature: 25
Operator: Aaron

Gamma Plane (°):0.0-180.0:1.0
Test Device: GPM-1800B
Distance: 9.028 m
Humidity: 60%
Inspector:


Coefficients Of Utilization - Zonal Cavity Method

RC	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.5	0.5	0.5	0.3	0.3	0.3	0.1	0.1	0.1	0
RW	0.7	0.5	0.3	0.1	0.7	0.5	0.3	0.1	0.5	0.3	0.1	0.5	0.3	0.1	0.5	0.3	0.1	0
RCR	RF = 0.2																	
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	101	101	101	99
1	108	103	99	95	106	101	97	94	97	93	90	93	90	88	89	87	85	83
2	98	90	83	77	96	88	81	76	84	79	74	81	76	72	78	74	71	68
3	89	79	70	64	87	77	69	63	74	67	62	71	65	61	68	64	59	57
4	82	69	60	54	79	68	60	53	65	58	52	63	57	52	61	55	51	49
5	75	62	53	46	73	61	52	46	58	51	45	56	50	44	54	49	44	42
6	69	56	46	40	67	55	46	40	53	45	39	51	44	39	49	43	38	36
7	64	50	41	35	62	49	41	35	48	40	35	46	39	34	45	39	34	32
8	60	46	37	31	58	45	37	31	44	36	31	42	36	31	41	35	30	28
9	56	42	34	28	54	41	33	28	40	33	28	39	32	28	38	32	27	25
10	52	39	31	25	51	38	30	25	37	30	25	36	30	25	35	29	25	23

Spacing Criteria (0-180): 1.30

Spacing Criteria (90-270): 1.30

Spacing Criteria (Diagonal): 1.43



C Plane (°):0.0-360.0: 30.0

Test Lab:

Test Type: TYPE C

Temperature: 25

Operator: Aaron

Gamma Plane (°):0.0-180.0:1.0


Test Device: GPM-1800B

Distance: 9.028 m

Humidity: 60%

Inspector:

Isocandela (rectangle)



Imax (100%): 88 cd

(10%):	9 cd	(20%):	18 cd
(25%):	22 cd	(30%):	26 cd
(40%):	35 cd	(50%):	44 cd
(60%):	53 cd	(70%):	61 cd
(80%):	70 cd	(90%):	79 cd

C Plane (°):0.0-360.0: 30.0

Test Lab:

Test Type: TYPE C

Temperature: 25

Operator: Aaron

Gamma Plane (°):0.0-180.0:1.0


Test Device: GPM-1800B

Distance: 9.028 m

Humidity: 60%

Inspector:

IsoLux Plot



Mounting Height: 5.0m Max Lux(100%): 3.5 lx

(10%): 0.4 lx	(20%): 0.7 lx
(25%): 0.9 lx	(30%): 1.1 lx
(40%): 1.4 lx	(50%): 1.8 lx
(60%): 2.1 lx	(70%): 2.5 lx
(80%): 2.8 lx	(90%): 3.2 lx

C Plane (°):0.0-360.0: 30.0

Test Lab:

Test Type: TYPE C

Temperature: 25

Operator: Aaron

Gamma Plane (°):0.0-180.0:1.0

Test Device: GPM-1800B

Distance: 9.028 m



Humidity: 60%

Inspector:

Lum Limit Curve

Dazzle	Quality	Illuminance (lx)							
1.15	A	2000	1000	500	<=300				
1.50	B		2000	1000	500	<=300			
1.85	C			2000	1000	500	<=300		
2.20	D				2000	1000	500	<=300	
2.55	E					2000	1000	500	<=300

a b c d e f g h



L(cd/sq.m)	G45	G50	G55	G60	G65	G70	G75	G80	G85
C0	33061	32220	31184	29737	27702	24983	21143	15894	9212
C90	37000	36815	36482	35860	34810	33125	30562	22419	6355
C180	32448	31537	30413	28935	26863	24013	20034	14785	7814
C270	36677	36531	36099	35396	34243	32401	29767	25669	9855

C Plane (°):0.0-360.0: 30.0

Test Lab:

Test Type: TYPE C

Temperature: 25

Operator: Aaron

Gamma Plane (°):0.0-180.0:1.0


Test Device: GPM-1800B

Distance: 9.028 m

Humidity: 60%

Inspector:

Illuminance at a Distance



C Plane (°):0.0-360.0: 30.0

Test Lab:

Test Type: TYPE C

Temperature: 25

Operator: Aaron

Gamma Plane (°):0.0-180.0:1.0


Test Device: GPM-1800B

Distance: 9.028 m

Humidity: 60%

Inspector:

Vertical IsoLux Plot



Lowest(m): 2.0m	Highest(m): 5.0m	Max Lux: 21.8 lx
(10%): 2.2 lx	(20%): 4.4 lx	
(25%): 5.5 lx	(30%): 6.5 lx	
(40%): 8.7 lx	(50%): 10.9 lx	
(60%): 13.1 lx	(70%): 15.3 lx	
(80%): 17.5 lx	(90%): 19.6 lx	

C Plane (°):0.0-360.0: 30.0
Test Lab:
Test Type: TYPE C
Temperature: 25
Operator: Aaron

Gamma Plane (°):0.0-180.0:1.0
Test Device: GPM-1800B
Distance: 9.028 m
Humidity: 60%
Inspector:

Area Flux Table


Unit: lm

Vertical plane		-90	-80	-70	-60	-50	-40	-30	-20	-10	0	10	20	30	40	50	60	70	80	90	Flux(T)	Flux(E)
		0.0	0.0	0.0	0.0	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.0	0.2	0.0
		0.0	0.0	0.1	0.1	0.2	0.3	0.5	0.7	1.0	1.2	1.3	1.3	1.3	1.3	1.3	1.3	1.3	1.3	0.0	1.6	1.4
		0.0	0.1	0.1	0.2	0.3	0.4	0.6	0.7	0.9	1.1	1.2	1.3	1.4	1.5	1.6	1.7	1.8	1.9	0.0	4.8	4.6
		0.0	0.1	0.2	0.3	0.5	0.7	1.0	1.2	1.4	1.5	1.6	1.7	1.8	1.9	2.0	2.1	2.2	2.3	0.0	9.4	9.2
		0.0	0.1	0.2	0.3	0.5	0.7	1.0	1.2	1.4	1.5	1.6	1.7	1.8	1.9	2.0	2.1	2.2	2.3	0.0	14.8	14.5
		0.0	0.1	0.2	0.3	0.5	0.7	1.0	1.2	1.4	1.5	1.6	1.7	1.8	1.9	2.0	2.1	2.2	2.3	0.0	20.1	19.9
		0.0	0.1	0.2	0.3	0.5	0.7	1.0	1.2	1.4	1.5	1.6	1.7	1.8	1.9	2.0	2.1	2.2	2.3	0.0	24.7	24.5
		0.0	0.1	0.2	0.3	0.5	0.7	1.0	1.2	1.4	1.5	1.6	1.7	1.8	1.9	2.0	2.1	2.2	2.3	0.0	28.0	27.9
		0.0	0.1	0.2	0.3	0.5	0.7	1.0	1.2	1.4	1.5	1.6	1.7	1.8	1.9	2.0	2.1	2.2	2.3	0.0	29.8	29.7
		0.0	0.1	0.2	0.3	0.5	0.7	1.0	1.2	1.4	1.5	1.6	1.7	1.8	1.9	2.0	2.1	2.2	2.3	0.0	29.9	29.7
		0.0	0.1	0.2	0.3	0.5	0.7	1.0	1.2	1.4	1.5	1.6	1.7	1.8	1.9	2.0	2.1	2.2	2.3	0.0	28.1	27.9
		0.0	0.1	0.2	0.3	0.5	0.7	1.0	1.2	1.4	1.5	1.6	1.7	1.8	1.9	2.0	2.1	2.2	2.3	0.0	24.8	24.6
		0.0	0.1	0.2	0.3	0.5	0.7	1.0	1.2	1.4	1.5	1.6	1.7	1.8	1.9	2.0	2.1	2.2	2.3	0.0	20.2	20.0
		0.0	0.1	0.2	0.3	0.5	0.7	1.0	1.2	1.4	1.5	1.6	1.7	1.8	1.9	2.0	2.1	2.2	2.3	0.0	14.9	14.7
		0.0	0.1	0.2	0.3	0.5	0.7	1.0	1.2	1.4	1.5	1.6	1.7	1.8	1.9	2.0	2.1	2.2	2.3	0.0	9.6	9.4
		0.0	0.1	0.2	0.3	0.5	0.7	1.0	1.2	1.4	1.5	1.6	1.7	1.8	1.9	2.0	2.1	2.2	2.3	0.0	4.9	4.7
		0.0	0.1	0.2	0.3	0.5	0.7	1.0	1.2	1.4	1.5	1.6	1.7	1.8	1.9	2.0	2.1	2.2	2.3	0.0	1.7	1.4
		0.0	0.1	0.2	0.3	0.5	0.7	1.0	1.2	1.4	1.5	1.6	1.7	1.8	1.9	2.0	2.1	2.2	2.3	0.0	0.2	0.0
		0.0	0.1	0.2	0.3	0.5	0.7	1.0	1.2	1.4	1.5	1.6	1.7	1.8	1.9	2.0	2.1	2.2	2.3	0.0	268	264

C Plane (°):0.0-360.0: 30.0
 Test Lab:
 Test Type: TYPE C
 Temperature: 25
 Operator: Aaron

Gamma Plane (°):0.0-180.0:1.0
 Test Device: GPM-1800B
 Distance: 9.028 m
 Humidity: 60%
 Inspector:

The Average Illuminance Effective Figure



C Plane (°):0.0-360.0: 30.0
 Test Lab:
 Test Type: TYPE C
 Temperature: 25
 Operator: Aaron

Gamma Plane (°):0.0-180.0:1.0
 Test Device: GPM-1800B
 Distance: 9.028 m
 Humidity: 60%
 Inspector:

UGR Table

Reflectance:										
Ceiling (cavity)	0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall	0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions	Viewed crosswise					Viewed endwise				
X=2H Y=2H	29.1	30.8	29.5	31.1	31.4	28.7	30.4	29.1	30.7	31.1
3H	31.0	32.5	31.4	32.8	33.2	30.5	32.0	30.9	32.3	32.7
4H	31.7	33.1	32.1	33.5	33.8	31.1	32.5	31.5	32.8	33.2
6H	32.2	33.5	32.6	33.9	34.3	31.4	32.7	31.8	33.1	33.5
8H	32.3	33.6	32.8	34.0	34.4	31.5	32.7	31.9	33.1	33.5
12H	32.4	33.6	32.9	34.0	34.5	31.5	32.7	31.9	33.1	33.5
X=4H Y=2H	29.7	31.1	30.1	31.5	31.9	29.4	30.8	29.8	31.2	31.6
3H	31.8	33.0	32.2	33.4	33.8	31.3	32.5	31.8	32.9	33.4
4H	32.6	33.6	33.0	34.1	34.5	32.1	33.1	32.5	33.6	34.0
6H	33.2	34.1	33.6	34.6	35.0	32.5	33.4	33.0	33.9	34.4
8H	33.4	34.2	33.8	34.7	35.2	32.6	33.5	33.1	33.9	34.4
12H	33.5	34.3	34.0	34.8	35.3	32.6	33.4	33.1	33.9	34.4
X=8H Y=4H	32.8	33.7	33.3	34.1	34.6	32.4	33.2	32.8	33.7	34.2
6H	33.5	34.2	34.0	34.7	35.2	32.9	33.6	33.4	34.1	34.6
8H	33.8	34.4	34.3	34.9	35.4	33.0	33.7	33.6	34.2	34.7
12H	34.0	34.5	34.5	35.0	35.6	33.1	33.7	33.6	34.2	34.7
X=12H Y=4H	32.8	33.6	33.3	34.1	34.6	32.4	33.2	32.9	33.7	34.2
6H	33.6	34.2	34.1	34.7	35.2	33.0	33.6	33.5	34.1	34.7
8H	33.8	34.4	34.3	34.9	35.5	33.1	33.7	33.7	34.2	34.8

Calculate in accordance with CIE 190:2010

C Plane (°):0.0-360.0: 30.0
 Test Lab:
 Test Type: TYPE C
 Temperature: 25
 Operator: Aaron

Gamma Plane (°):0.0-180.0:1.0
 Test Device: GPM-1800B
 Distance: 9.028 m
 Humidity: 60%
 Inspector:

Utilisation Factor Table(Floor cavity)

Utilisation Factors UF(F)			SHR NOM = 1.50									
Room Reflectance			Room Index(RI)									
Ceiling	Wall	Floor	0.75	1.00	1.25	1.50	2.00	2.50	3.00	4.00	5.00	
0.70	0.50	0.20	0.59	0.67	0.75	0.80	0.87	0.92	0.96	1.00	1.03	
	0.30		0.51	0.59	0.67	0.73	0.81	0.87	0.91	0.96	1.00	
	0.20		0.45	0.54	0.62	0.68	0.76	0.82	0.86	0.92	0.97	
0.50	0.50	0.20	0.57	0.65	0.72	0.77	0.84	0.89	0.92	0.96	0.99	
	0.30		0.50	0.58	0.66	0.71	0.79	0.84	0.88	0.93	0.96	
	0.20		0.45	0.53	0.61	0.66	0.74	0.80	0.84	0.90	0.93	
0.30	0.50	0.20	0.55	0.63	0.70	0.75	0.81	0.85	0.88	0.92	0.95	
	0.30		0.49	0.57	0.64	0.70	0.77	0.82	0.85	0.90	0.93	
	0.20		0.45	0.52	0.60	0.65	0.73	0.78	0.82	0.87	0.90	
0.00	0.00	0.00	0.42	0.50	0.57	0.62	0.69	0.74	0.78	0.83	0.86	
Rating:2W Photometrically tested without ceiling board. Multiply UF values by service correction factors Calculate in accordance with CIBSE Technical Memorandum NO.5 1980												

Utilisation Factor Table(Wall)

Utilisation Factors UF(W)			SHR NOM = 1.50									
Room Reflectance			Room Index(RI)									
Ceiling	Wall	Floor	0.75	1.00	1.25	1.50	2.00	2.50	3.00	4.00	5.00	
0.70	0.50	0.20	0.97	0.82	0.69	0.60	0.48	0.40	0.34	0.27	0.22	
	0.30		0.81	0.70	0.61	0.53	0.44	0.37	0.32	0.25	0.21	
	0.20		0.69	0.61	0.54	0.48	0.40	0.34	0.30	0.24	0.20	
0.50	0.50	0.20	0.93	0.79	0.66	0.58	0.46	0.42	0.33	0.25	0.20	
	0.30		0.79	0.68	0.59	0.52	0.42	0.35	0.31	0.24	0.20	
	0.20		0.68	0.60	0.53	0.47	0.39	0.33	0.29	0.23	0.19	
0.30	0.50	0.20	0.90	0.76	0.64	0.55	0.44	0.36	0.31	0.24	0.20	
	0.30		0.77	0.67	0.57	0.50	0.41	0.34	0.29	0.23	0.19	
	0.20		0.67	0.60	0.52	0.46	0.38	0.32	0.28	0.22	0.18	
0.00	0.00	0.00	0.57	0.50	0.42	0.37	0.30	0.25	0.22	0.17	0.14	
Rating:2W Photometrically tested without ceiling board. Multiply UF values by service correction factors Calculate in accordance with CIBSE Technical Memorandum NO.5 1980												

C Plane (°):0.0-360.0: 30.0

Test Lab:

Test Type: TYPE C

Temperature: 25

Operator: Aaron

Gamma Plane (°):0.0-180.0:1.0

Test Device: GPM-1800B

Distance: 9.028 m

Humidity: 60%

Inspector:

Utilisation Factor Table(Ceiling cavity)

Utilisation Factors UF(C)			SHR NOM = 1.50									
Room Reflectance			Room Index(RI)									
Ceiling	Wall	Floor	0.75	1.00	1.25	1.50	2.00	2.50	3.00	4.00	5.00	
0.70	0.50	0.20	0.17	0.18	0.19	0.20	0.21	0.21	0.21	0.22	0.22	
	0.30		0.10	0.12	0.13	0.14	0.16	0.17	0.18	0.19	0.20	
	0.20		0.05	0.07	0.08	0.10	0.12	0.13	0.14	0.16	0.17	
0.50	0.50	0.20	0.16	0.17	0.18	0.19	0.20	0.20	0.21	0.21	0.21	
	0.30		0.10	0.11	0.13	0.14	0.15	0.16	0.17	0.18	0.19	
	0.20		0.05	0.07	0.08	0.09	0.11	0.13	0.14	0.16	0.17	
0.30	0.50	0.20	0.16	0.17	0.18	0.18	0.19	0.19	0.20	0.20	0.20	
	0.30		0.10	0.11	0.12	0.13	0.15	0.16	0.17	0.18	0.18	
	0.20		0.05	0.07	0.08	0.09	0.11	0.13	0.14	0.15	0.16	
0.00	0.00	0.00	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	
Rating:2W Photometrically tested without ceiling board. Multiply UF values by service correction factors Calculate in accordance with CIBSE Technical Memorandum NO.5 1980												

C Plane (°):0.0-360.0: 30.0

Test Lab:

Test Type: TYPE C

Temperature: 25

Operator: Aaron

Gamma Plane (°):0.0-180.0:1.0

Test Device: GPM-1800B

Distance: 9.028 m

Humidity: 60%

Inspector: