

Report No.:

Test Time: 2020/12/29 16:14

Luminaire Property

Luminaire Manufacturer: ACOLYTE

Luminaire Category: CHANNEL

Lamp Catalog: RIBBONLYTE

Number of Lamps: 1 ROW

Luminous Width (mm): 18.7

Voltage: 24.0 V

Power: 5.31 W

Luminaire Description: AR10

Lamp Description: RB90SWS2203.030

Luminous Length (mm): 500

Luminous Height (mm): 12

Current: 0.221 A

Power Factor: 1.000

Photometric Results

CIE Class: Direct

Measurement Flux: 211.3 lm

Downward Ratio: 99%

Horizontal Diffuse Angle(10%,50%): H159.3,H108.3

Vertical Diffuse Angle(10%,50%): V161.3,V110

Luminaire Efficacy Rating (LER): 40

Max. Intensity: 76.06 cd

Total Rated Lamp Lumens: 211.3 lm

Efficiency: 100%

Upward Ratio: 1%


Central Intensity: 76 cd

Pos of Max. Intensity: H150 V0

Picture Of Luminaire



Luminous Intensity Distribution Curve



Average Diffuse Angle(50%): 109.1° Unit: cd

— C0-C180 — C90-C270

C Plane (°):0.0-360.0: 30.0

Test Lab:

Test Type: TYPE C

Temperature: 25

Operator: Nick

Gamma Plane (°):0.0-180.0: 1.0

Test Device: GPM-1800B



Distance: 9.028 m

Humidity: 60%

Inspector:



Luminous Intensity Distribution Curve



Unit: cd

C Plane (°):0.0-360.0: 30.0

Test Lab:

Test Type: TYPE C

Temperature: 25

Operator: Nick

Gamma Plane (°):0.0-180.0:1.0


Test Device: GPM-1800B

Distance: 9.028 m

Humidity: 60%

Inspector:

Luminous Intensity Distribution Curve(cd/klm)



C Plane (°):0.0-360.0: 30.0

Test Lab:

Test Type: TYPE C

Temperature: 25

Operator: Nick

Gamma Plane (°):0.0-180.0: 1.0

Test Device: GPM-1800B

Distance: 9.028 m

Humidity: 60%

Inspector:


Coefficients Of Utilization - Zonal Cavity Method

RC	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.5	0.5	0.5	0.3	0.3	0.3	0.1	0.1	0.1	0
RW	0.7	0.5	0.3	0.1	0.7	0.5	0.3	0.1	0.5	0.3	0.1	0.5	0.3	0.1	0.5	0.3	0.1	0
RCR	RF = 0.2																	
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	101	101	101	99
1	109	104	100	96	106	101	98	94	97	94	91	93	90	88	89	87	85	83
2	99	91	84	78	96	89	82	77	85	80	75	81	77	73	78	75	71	69
3	90	80	71	65	87	78	70	64	75	68	63	72	66	62	69	64	61	58
4	82	70	62	55	80	69	61	55	66	59	54	64	58	53	62	56	52	50
5	76	63	54	47	74	62	53	47	60	52	46	57	51	46	55	50	45	43
6	70	57	48	41	68	56	47	41	54	46	41	52	45	40	50	44	40	38
7	65	51	43	37	63	51	42	36	49	41	36	47	41	36	46	40	35	33
8	60	47	38	33	59	46	38	32	45	37	32	43	37	32	42	36	32	30
9	56	43	35	29	55	42	35	29	41	34	29	40	34	29	39	33	29	27
10	53	40	32	27	52	39	32	26	38	31	26	37	31	26	36	30	26	24

Spacing Criteria (0-180): 1.22

Spacing Criteria (90-270): 1.23

Spacing Criteria (Diagonal): 1.35



C Plane (°):0.0-360.0: 30.0

Test Lab:

Test Type: TYPE C

Temperature: 25

Operator: Nick

Gamma Plane (°):0.0-180.0: 1.0


Test Device: GPM-1800B

Distance: 9.028 m

Humidity: 60%

Inspector:

Isocandela (rectangle)



I_{max} (100%): 76 cd

(10%):	8 cd	(20%):	15 cd
(25%):	19 cd	(30%):	23 cd
(40%):	30 cd	(50%):	38 cd
(60%):	46 cd	(70%):	53 cd
(80%):	61 cd	(90%):	68 cd

C Plane (°):0.0-360.0: 30.0

Test Lab:

Test Type: TYPE C

Temperature: 25

Operator: Nick

Gamma Plane (°):0.0-180.0:1.0


Test Device: GPM-1800B

Distance: 9.028 m

Humidity: 60%

Inspector:

IsoLux Plot



Mounting Height: 5.0m Max Lux(100%): 3.0 lx

(10%): 0.3 lx	(20%): 0.6 lx
(25%): 0.8 lx	(30%): 0.9 lx
(40%): 1.2 lx	(50%): 1.5 lx
(60%): 1.8 lx	(70%): 2.1 lx
(80%): 2.4 lx	(90%): 2.7 lx

C Plane (°):0.0-360.0: 30.0

Test Lab:

Test Type: TYPE C

Temperature: 25

Operator: Nick

Gamma Plane (°):0.0-180.0:1.0

Test Device: GPM-1800B

Distance: 9.028 m

Humidity: 60%



Inspector:



Lum Limit Curve

Dazzle	Quality	Illuminance (lx)							
1.15	A	2000	1000	500	<=300				
1.50	B		2000	1000	500	<=300			
1.85	C			2000	1000	500	<=300		
2.20	D				2000	1000	500	<=300	
2.55	E					2000	1000	500	<=300

a b c d e f g h



L(cd/sq.m)	G45	G50	G55	G60	G65	G70	G75	G80	G85
C0	4442	4035	3617	3157	2673	2137	1567	964	372
C90	7291	7148	6946	6720	6445	6087	5689	4917	3515
C180	4431	4020	3599	3148	2657	2130	1559	943	365
C270	7168	6982	6730	6424	6070	5591	4995	4039	2205

C Plane (°):0.0-360.0: 30.0

Test Lab:

Test Type: TYPE C

Temperature: 25

Operator: Nick

Gamma Plane (°):0.0-180.0:1.0

Test Device: GPM-1800B


Distance: 9.028 m

Humidity: 60%

Inspector:



Illuminance at a Distance



C Plane (°):0.0-360.0: 30.0

Test Lab:

Test Type: TYPE C

Temperature: 25

Operator: Nick

Gamma Plane (°):0.0-180.0: 1.0


Test Device: GPM-1800B

Distance: 9.028 m

Humidity: 60%

Inspector:

Vertical IsoLux Plot



Lowest(m): 2.0m	Highest(m): 5.0m	Max Lux: 19.0 lx
(10%): 1.9 lx	(20%): 3.8 lx	
(25%): 4.8 lx	(30%): 5.7 lx	
(40%): 7.6 lx	(50%): 9.5 lx	
(60%): 11.4 lx	(70%): 13.3 lx	
(80%): 15.2 lx	(90%): 17.1 lx	

C Plane (°):0.0-360.0: 30.0

Test Lab:

Test Type: TYPE C

Temperature: 25

Operator: Nick

Gamma Plane (°):0.0-180.0:1.0

Test Device: GPM-1800B

Distance: 9.028 m

Humidity: 60%

Inspector:

Area Flux Table

Unit: lm

Vertical plane		-90	-80	-70	-60	-50	-40	-30	-20	-10	0	10	20	30	40	50	60	70	80	90	Flux(T)	Flux(E)
Horizontal plane	-90	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0
	-80	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.1	0.8
	-70	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	3.4	3.2
	-60	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	6.9	6.7
	-50	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	11.1	10.9
	-40	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	15.5	15.3
	-30	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	19.5	19.3
	-20	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	22.6	22.4
	-10	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	24.3	24.1
	0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	24.3	24.1
	10	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	22.6	22.4
	20	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	19.5	19.4
	30	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	15.5	15.4
	40	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	11.1	11.0
	50	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	6.9	6.8
	60	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	3.4	3.3
	70	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.1	0.9
	80	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0
	90	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	209	206
	Flux(E)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		

C Plane (°):0.0-360.0: 30.0

Test Lab:

Test Type: TYPE C

Temperature: 25

Operator: Nick

Gamma Plane (°):0.0-180.0:1.0

Test Device: GPM-1800B


Distance: 9.028 m

Humidity: 60%

Inspector:



The Average Illuminance Effective Figure



UGR Table

Reflectance:										
Ceiling (cavity)	0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall	0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions	Viewed crosswise					Viewed endwise				
X=2H Y=2H	23.1	24.7	23.5	25.1	25.4	22.0	23.6	22.4	24.0	24.3
3H	24.9	26.3	25.2	26.7	27.0	23.5	25.0	23.9	25.3	25.7
4H	25.5	26.8	25.9	27.2	27.6	24.0	25.4	24.4	25.7	26.1
6H	25.9	27.1	26.3	27.5	27.9	24.3	25.6	24.7	25.9	26.4
8H	26.0	27.2	26.4	27.6	28.0	24.4	25.6	24.8	26.0	26.4
12H	26.0	27.2	26.5	27.6	28.0	24.4	25.5	24.8	25.9	26.4
X=4H Y=2H	23.5	24.9	23.9	25.3	25.7	22.7	24.0	23.1	24.4	24.8
3H	25.4	26.6	25.8	27.0	27.4	24.3	25.5	24.7	25.9	26.3
4H	26.1	27.2	26.6	27.6	28.1	24.9	25.9	25.4	26.4	26.8
6H	26.6	27.5	27.1	28.0	28.5	25.3	26.2	25.8	26.7	27.1
8H	26.7	27.6	27.2	28.1	28.5	25.4	26.2	25.9	26.7	27.2
12H	26.8	27.6	27.3	28.1	28.6	25.4	26.2	25.9	26.7	27.2
X=8H Y=4H	26.3	27.1	26.7	27.6	28.1	25.2	26.0	25.6	26.5	27.0
6H	26.8	27.5	27.3	28.0	28.5	25.6	26.3	26.1	26.8	27.3
8H	27.0	27.6	27.5	28.1	28.6	25.8	26.4	26.3	26.9	27.4
12H	27.1	27.6	27.6	28.1	28.7	25.8	26.4	26.4	26.9	27.5
X=12H Y=4H	26.3	27.0	26.8	27.5	28.0	25.2	25.9	25.7	26.4	26.9
6H	26.8	27.5	27.4	27.9	28.5	25.7	26.3	26.2	26.8	27.3
8H	27.0	27.6	27.5	28.1	28.6	25.8	26.4	26.3	26.9	27.5

Calculate in accordance with CIE 190:2010

C Plane (°):0.0-360.0: 30.0
Test Lab:
Test Type: TYPE C
Temperature: 25
Operator: Nick

Gamma Plane (°):0.0-180.0: 1.0
Test Device: GPM-1800B
Distance: 9.028 m
Humidity: 60%
Inspector:

Utilisation Factor Table(Floor cavity)

Utilisation Factors UF(F)			SHR NOM = 1.25								
Room Reflectance			Room Index(RI)								
Ceiling	Wall	Floor	0.75	1.00	1.25	1.50	2.00	2.50	3.00	4.00	5.00
0.70	0.50	0.20	0.57	0.67	0.74	0.80	0.87	0.92	0.96	1.00	1.03
	0.30		0.49	0.59	0.67	0.73	0.81	0.87	0.91	0.96	1.00
	0.20		0.43	0.54	0.61	0.67	0.76	0.82	0.86	0.93	0.97
0.50	0.50	0.20	0.55	0.65	0.72	0.77	0.84	0.89	0.92	0.96	0.99
	0.30		0.48	0.58	0.65	0.71	0.79	0.84	0.88	0.93	0.96
	0.20		0.43	0.53	0.60	0.66	0.74	0.80	0.84	0.90	0.93
0.30	0.50	0.20	0.53	0.63	0.69	0.74	0.81	0.85	0.88	0.92	0.95
	0.30		0.47	0.57	0.64	0.69	0.76	0.81	0.85	0.89	0.92
	0.20		0.42	0.52	0.60	0.65	0.73	0.78	0.82	0.87	0.90
0.00	0.00	0.00	0.40	0.50	0.57	0.62	0.69	0.74	0.78	0.82	0.85
Rating:5W Photometrically tested without ceiling board. Multiply UF values by service correction factors Calculate in accordance with CIBSE Technical Memorandum NO.5 1980											

Utilisation Factor Table(Wall)

Utilisation Factors UF(W)			SHR NOM = 1.25									
Room Reflectance			Room Index(RI)									
Ceiling	Wall	Floor	0.75	1.00	1.25	1.50	2.00	2.50	3.00	4.00	5.00	
0.70	0.50	0.20	0.99	0.82	0.70	0.61	0.48	0.40	0.34	0.26	0.22	
	0.30		0.83	0.70	0.61	0.54	0.44	0.37	0.32	0.25	0.21	
	0.20		0.71	0.61	0.54	0.48	0.40	0.34	0.30	0.23	0.20	
0.50	0.50	0.20	0.96	0.79	0.67	0.58	0.46	0.41	0.33	0.25	0.20	
	0.30		0.81	0.68	0.59	0.52	0.42	0.35	0.30	0.24	0.20	
	0.20		0.70	0.60	0.53	0.47	0.39	0.33	0.29	0.23	0.19	
0.30	0.50	0.20	0.93	0.75	0.64	0.56	0.44	0.36	0.31	0.24	0.20	
	0.30		0.79	0.66	0.57	0.50	0.41	0.34	0.29	0.23	0.19	
	0.20		0.69	0.59	0.52	0.46	0.38	0.32	0.28	0.22	0.18	
0.00	0.00	0.00	0.59	0.49	0.43	0.37	0.30	0.25	0.22	0.17	0.14	
<p>Rating:5W Photometrically tested without ceiling board.</p> <p>Multiply UF values by service correction factors</p> <p>Calculate in accordance with CIBSE Technical Memorandum NO.5 1980</p>												

Utilisation Factor Table(Ceiling cavity)

Utilisation Factors UF(C)			SHR NOM = 1.25								
Room Reflectance			Room Index(RI)								
Ceiling	Wall	Floor	0.75	1.00	1.25	1.50	2.00	2.50	3.00	4.00	5.00
0.70	0.50	0.20	0.17	0.19	0.19	0.20	0.21	0.21	0.22	0.22	0.23
	0.30		0.10	0.12	0.13	0.14	0.16	0.17	0.18	0.19	0.20
	0.20		0.06	0.07	0.09	0.10	0.12	0.14	0.15	0.17	0.18
0.50	0.50	0.20	0.17	0.18	0.19	0.19	0.20	0.21	0.21	0.22	0.22
	0.30		0.10	0.12	0.13	0.14	0.16	0.17	0.18	0.19	0.19
	0.20		0.06	0.07	0.09	0.10	0.12	0.13	0.15	0.16	0.17
0.30	0.50	0.20	0.16	0.17	0.18	0.19	0.19	0.20	0.20	0.21	0.21
	0.30		0.10	0.12	0.13	0.14	0.15	0.16	0.17	0.18	0.19
	0.20		0.06	0.07	0.09	0.10	0.12	0.13	0.14	0.16	0.17
0.00	0.00	0.00	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01
Rating:5W Photometrically tested without ceiling board. Multiply UF values by service correction factors Calculate in accordance with CIBSE Technical Memorandum NO.5 1980											

Zonal Lumen

Gamma [°]	I _{mean} [cd]	Zonal Flux [lm]	Sum Zonal Flux [lm]	Rel Zonal Flux [%]	Sum Rel Zonal Flux [%]
0.0-1.0	76.0	0.1	0.1	0.03	0.03
1.0-2.0	76.0	0.2	0.3	0.10	0.14
2.0-3.0	75.9	0.4	0.7	0.17	0.31
3.0-4.0	75.8	0.5	1.2	0.24	0.55
4.0-5.0	75.7	0.7	1.8	0.31	0.86
5.0-6.0	75.5	0.8	2.6	0.38	1.23
6.0-7.0	75.3	0.9	3.5	0.44	1.68
7.0-8.0	75.1	1.1	4.6	0.51	2.18
8.0-9.0	74.8	1.2	5.8	0.57	2.76
9.0-10.0	74.5	1.3	7.2	0.64	3.40
10.0-11.0	74.2	1.5	8.7	0.70	4.10
11.0-12.0	73.9	1.6	10.3	0.76	4.86
12.0-13.0	73.5	1.7	12.0	0.83	5.69
13.0-14.0	73.1	1.9	13.9	0.89	6.57
14.0-15.0	72.6	2.0	15.9	0.94	7.52
15.0-16.0	72.2	2.1	18.0	1.00	8.52
16.0-17.0	71.7	2.2	20.2	1.06	9.58
17.0-18.0	71.2	2.3	22.6	1.11	10.69
18.0-19.0	70.6	2.5	25.0	1.16	11.85
19.0-20.0	70.0	2.6	27.6	1.21	13.06
20.0-21.0	69.5	2.7	30.3	1.26	14.33
21.0-22.0	68.8	2.8	33.0	1.31	15.63
22.0-23.0	68.2	2.9	35.9	1.35	16.99
23.0-24.0	67.5	3.0	38.8	1.40	18.39
24.0-25.0	66.8	3.0	41.9	1.44	19.82
25.0-26.0	66.1	3.1	45.0	1.48	21.30
26.0-27.0	65.4	3.2	48.2	1.51	22.82
27.0-28.0	64.6	3.3	51.5	1.55	24.37
28.0-29.0	63.9	3.3	54.8	1.58	25.95
29.0-30.0	63.1	3.4	58.2	1.61	27.56
30.0-31.0	62.2	3.5	61.7	1.64	29.20
31.0-32.0	61.4	3.5	65.2	1.67	30.86
32.0-33.0	60.6	3.6	68.8	1.69	32.55
33.0-34.0	59.7	3.6	72.4	1.71	34.26
34.0-35.0	58.8	3.7	76.0	1.73	35.99
35.0-36.0	57.9	3.7	79.7	1.75	37.74

C Plane (°):0.0-360.0: 30.0

Test Lab:

Test Type: TYPE C

Temperature: 25

Operator: Nick

Gamma Plane (°):0.0-180.0:1.0

Test Device: GPM-1800B

Distance: 9.028 m

Humidity: 60%

Inspector:

Zonal Lumen (Continue 1)

Gamma [°]	I _{mean} [cd]	Zonal Flux [lm]	Sum Zonal Flux [lm]	Rel Zonal Flux [%]	Sum Rel Zonal Flux [%]
36.0-37.0	57.0	3.7	83.4	1.76	39.50
37.0-38.0	56.0	3.7	87.2	1.77	41.27
38.0-39.0	55.1	3.8	90.9	1.78	43.05
39.0-40.0	54.1	3.8	94.7	1.79	44.83
40.0-41.0	53.1	3.8	98.5	1.79	46.63
41.0-42.0	52.2	3.8	102.3	1.79	48.42
42.0-43.0	51.2	3.8	106.1	1.80	50.22
43.0-44.0	50.2	3.8	109.9	1.79	52.01
44.0-45.0	49.1	3.8	113.7	1.79	53.79
45.0-46.0	48.1	3.8	117.4	1.78	55.57
46.0-47.0	47.0	3.7	121.2	1.77	57.35
47.0-48.0	46.0	3.7	124.9	1.76	59.11
48.0-49.0	44.9	3.7	128.6	1.75	60.85
49.0-50.0	43.8	3.7	132.2	1.73	62.58
50.0-51.0	42.7	3.6	135.8	1.71	64.29
51.0-52.0	41.6	3.6	139.4	1.69	65.99
52.0-53.0	40.5	3.5	142.9	1.67	67.65
53.0-54.0	39.4	3.5	146.4	1.64	69.30
54.0-55.0	38.2	3.4	149.8	1.62	70.91
55.0-56.0	37.1	3.4	153.2	1.59	72.50
56.0-57.0	35.9	3.3	156.5	1.55	74.05
57.0-58.0	34.7	3.2	159.7	1.52	75.57
58.0-59.0	33.5	3.1	162.8	1.48	77.06
59.0-60.0	32.3	3.1	165.9	1.45	78.50
60.0-61.0	31.1	3.0	168.8	1.41	79.91
61.0-62.0	29.9	2.9	171.7	1.37	81.27
62.0-63.0	28.7	2.8	174.5	1.32	82.60
63.0-64.0	27.5	2.7	177.2	1.28	83.88
64.0-65.0	26.3	2.6	179.8	1.23	85.11
65.0-66.0	25.1	2.5	182.3	1.19	86.29
66.0-67.0	23.9	2.4	184.7	1.14	87.43
67.0-68.0	22.6	2.3	187.0	1.09	88.52
68.0-69.0	21.4	2.2	189.2	1.04	89.55
69.0-70.0	20.2	2.1	191.3	0.98	90.53
70.0-71.0	19.0	2.0	193.2	0.93	91.46
71.0-72.0	17.8	1.8	195.1	0.88	92.34

C Plane (°):0.0-360.0: 30.0

Test Lab:

Test Type: TYPE C

Temperature: 25

Operator: Nick

Gamma Plane (°):0.0-180.0:1.0

Test Device: GPM-1800B

Distance: 9.028 m

Humidity: 60%

Inspector:

Zonal Lumen (Continue 2)

Gamma [°]	I _{mean} [cd]	Zonal Flux [lm]	Sum Zonal Flux [lm]	Rel Zonal Flux [%]	Sum Rel Zonal Flux [%]
72.0-73.0	16.6	1.7	196.8	0.82	93.16
73.0-74.0	15.4	1.6	198.4	0.77	93.92
74.0-75.0	14.2	1.5	199.9	0.71	94.63
75.0-76.0	13.0	1.4	201.3	0.65	95.29
76.0-77.0	11.8	1.3	202.6	0.60	95.89
77.0-78.0	10.7	1.1	203.7	0.54	96.43
78.0-79.0	9.6	1.0	204.8	0.49	96.91
79.0-80.0	8.4	0.9	205.7	0.43	97.34
80.0-81.0	7.3	0.8	206.5	0.37	97.72
81.0-82.0	6.2	0.7	207.1	0.32	98.04
82.0-83.0	5.2	0.6	207.7	0.27	98.30
83.0-84.0	4.2	0.5	208.1	0.22	98.52
84.0-85.0	3.2	0.4	208.5	0.17	98.69
85.0-86.0	2.3	0.3	208.8	0.12	98.81
86.0-87.0	1.5	0.2	208.9	0.08	98.89
87.0-88.0	0.9	0.1	209.0	0.04	98.93
88.0-89.0	0.4	0.0	209.1	0.02	98.95
89.0-90.0	0.2	0.0	209.1	0.01	98.96
90.0-91.0	0.1	0.0	209.1	0.01	98.97
91.0-92.0	0.1	0.0	209.1	0.01	98.97
92.0-93.0	0.1	0.0	209.1	0.01	98.98
93.0-94.0	0.1	0.0	209.1	0.01	98.98
94.0-95.0	0.1	0.0	209.1	0.01	98.99
95.0-96.0	0.1	0.0	209.2	0.01	99.00
96.0-97.0	0.1	0.0	209.2	0.01	99.00
97.0-98.0	0.1	0.0	209.2	0.01	99.01
98.0-99.0	0.2	0.0	209.2	0.01	99.02
99.0-100.0	0.2	0.0	209.2	0.01	99.03
100.0-101.0	0.2	0.0	209.2	0.01	99.04
101.0-102.0	0.2	0.0	209.3	0.01	99.05
102.0-103.0	0.2	0.0	209.3	0.01	99.06
103.0-104.0	0.2	0.0	209.3	0.01	99.07
104.0-105.0	0.2	0.0	209.3	0.01	99.08
105.0-106.0	0.2	0.0	209.3	0.01	99.09
106.0-107.0	0.2	0.0	209.4	0.01	99.10
107.0-108.0	0.2	0.0	209.4	0.01	99.11

C Plane (°):0.0-360.0: 30.0

Test Lab:

Test Type: TYPE C

Temperature: 25

Operator: Nick

Gamma Plane (°):0.0-180.0:1.0

Test Device: GPM-1800B

Distance: 9.028 m

Humidity: 60%

Inspector:

Zonal Lumen (Continue 3)

Gamma [°]	I _{mean} [cd]	Zonal Flux [lm]	Sum Zonal Flux [lm]	Rel Zonal Flux [%]	Sum Rel Zonal Flux [%]
108.0-109.0	0.2	0.0	209.4	0.01	99.12
109.0-110.0	0.2	0.0	209.4	0.01	99.13
110.0-111.0	0.3	0.0	209.5	0.01	99.15
111.0-112.0	0.3	0.0	209.5	0.01	99.16
112.0-113.0	0.3	0.0	209.5	0.01	99.17
113.0-114.0	0.3	0.0	209.6	0.01	99.18
114.0-115.0	0.3	0.0	209.6	0.01	99.20
115.0-116.0	0.3	0.0	209.6	0.01	99.21
116.0-117.0	0.3	0.0	209.6	0.01	99.23
117.0-118.0	0.3	0.0	209.7	0.02	99.24
118.0-119.0	0.3	0.0	209.7	0.02	99.26
119.0-120.0	0.3	0.0	209.7	0.01	99.27
120.0-121.0	0.3	0.0	209.8	0.02	99.29
121.0-122.0	0.4	0.0	209.8	0.02	99.30
122.0-123.0	0.4	0.0	209.8	0.02	99.32
123.0-124.0	0.4	0.0	209.9	0.02	99.34
124.0-125.0	0.4	0.0	209.9	0.02	99.35
125.0-126.0	0.4	0.0	209.9	0.02	99.37
126.0-127.0	0.4	0.0	210.0	0.02	99.38
127.0-128.0	0.4	0.0	210.0	0.02	99.40
128.0-129.0	0.4	0.0	210.0	0.02	99.42
129.0-130.0	0.4	0.0	210.1	0.02	99.43
130.0-131.0	0.4	0.0	210.1	0.02	99.45
131.0-132.0	0.4	0.0	210.2	0.02	99.47
132.0-133.0	0.4	0.0	210.2	0.02	99.48
133.0-134.0	0.4	0.0	210.2	0.02	99.50
134.0-135.0	0.5	0.0	210.3	0.02	99.52
135.0-136.0	0.5	0.0	210.3	0.02	99.53
136.0-137.0	0.5	0.0	210.3	0.02	99.55
137.0-138.0	0.5	0.0	210.4	0.02	99.57
138.0-139.0	0.5	0.0	210.4	0.02	99.58
139.0-140.0	0.5	0.0	210.4	0.02	99.60
140.0-141.0	0.5	0.0	210.5	0.02	99.62
141.0-142.0	0.5	0.0	210.5	0.02	99.63
142.0-143.0	0.5	0.0	210.5	0.02	99.65
143.0-144.0	0.5	0.0	210.6	0.02	99.67

C Plane (°):0.0-360.0: 30.0

Test Lab:

Test Type: TYPE C

Temperature: 25

Operator: Nick

Gamma Plane (°):0.0-180.0:1.0

Test Device: GPM-1800B

Distance: 9.028 m

Humidity: 60%

Inspector:

Zonal Lumen (Continue 4)

Gamma [°]	I _{mean} [cd]	Zonal Flux [lm]	Sum Zonal Flux [lm]	Rel Zonal Flux [%]	Sum Rel Zonal Flux [%]
144.0-145.0	0.5	0.0	210.6	0.02	99.68
145.0-146.0	0.5	0.0	210.6	0.02	99.70
146.0-147.0	0.5	0.0	210.7	0.02	99.71
147.0-148.0	0.5	0.0	210.7	0.02	99.73
148.0-149.0	0.6	0.0	210.7	0.02	99.74
149.0-150.0	0.5	0.0	210.8	0.01	99.76
150.0-151.0	0.5	0.0	210.8	0.01	99.77
151.0-152.0	0.6	0.0	210.8	0.01	99.79
152.0-153.0	0.6	0.0	210.9	0.01	99.80
153.0-154.0	0.6	0.0	210.9	0.01	99.81
154.0-155.0	0.6	0.0	210.9	0.01	99.83
155.0-156.0	0.6	0.0	210.9	0.01	99.84
156.0-157.0	0.6	0.0	211.0	0.01	99.85
157.0-158.0	0.6	0.0	211.0	0.01	99.86
158.0-159.0	0.6	0.0	211.0	0.01	99.87
159.0-160.0	0.6	0.0	211.0	0.01	99.89
160.0-161.0	0.6	0.0	211.1	0.01	99.90
161.0-162.0	0.6	0.0	211.1	0.01	99.91
162.0-163.0	0.6	0.0	211.1	0.01	99.92
163.0-164.0	0.6	0.0	211.1	0.01	99.93
164.0-165.0	0.6	0.0	211.1	0.01	99.93
165.0-166.0	0.6	0.0	211.2	0.01	99.94
166.0-167.0	0.6	0.0	211.2	0.01	99.95
167.0-168.0	0.7	0.0	211.2	0.01	99.96
168.0-169.0	0.7	0.0	211.2	0.01	99.96
169.0-170.0	0.6	0.0	211.2	0.01	99.97
170.0-171.0	0.7	0.0	211.2	0.01	99.98
171.0-172.0	0.7	0.0	211.2	0.01	99.98
172.0-173.0	0.7	0.0	211.2	0.00	99.99
173.0-174.0	0.7	0.0	211.3	0.00	99.99
174.0-175.0	0.7	0.0	211.3	0.00	99.99
175.0-176.0	0.7	0.0	211.3	0.00	100.00
176.0-177.0	0.7	0.0	211.3	0.00	100.00
177.0-178.0	0.7	0.0	211.3	0.00	100.00
178.0-179.0	0.7	0.0	211.3	0.00	100.00
179.0-180.0	0.7	0.0	211.3	0.00	100.00

C Plane (°):0.0-360.0: 30.0

Test Lab:

Test Type: TYPE C

Temperature: 25

Operator: Nick

Gamma Plane (°):0.0-180.0:1.0

Test Device: GPM-1800B

Distance: 9.028 m

Humidity: 60%

Inspector: