

Report No.:

Test Time: 2021/2/19 09:59

Luminaire Property

Luminaire Manufacturer:

Luminaire Category: CHANNEL

Lamp Catalog: RIBBONLYTE

Number of Lamps: 1 ROWS

Luminous Width (mm): 24

Voltage: 24.0 V

Power: 5.52 W

Luminaire Description: AS14

Lamp Description: RB90SWS2203.030

Luminous Length (mm): 500

Luminous Height (mm): 9

Current: 0.230 A

Power Factor: 1.000

Photometric Results

CIE Class: Direct

Measurement Flux: 304.7 lm

Downward Ratio: 99%

Horizontal Diffuse Angle(10%,50%): H161.4,H110.4

Vertical Diffuse Angle(10%,50%): V160.1,V111.1

Luminaire Efficacy Rating (LER): 55

Max. Intensity: 108.05 cd

Total Rated Lamp Lumens: 304.7 lm


Efficiency: 100%

Upward Ratio: 1%


Central Intensity: 107.91 cd

Pos of Max. Intensity: H120 V0

Picture Of Luminaire



Luminous Intensity Distribution Curve



Average Diffuse Angle(50%): 110.8° Unit: cd

— C0-C180 — C90-C270

C Plane (°):0.0-360.0: 30.0

Test Lab:

Test Type: TYPE C

Temperature: 25

Operator: Nick

Gamma Plane (°):0.0-180.0: 1.0

Test Device: GPM-1800B


Distance: 9.028 m

Humidity: 60%

Inspector:




Luminous Intensity Distribution Curve



C Plane (°):0.0-360.0: 30.0
Test Lab:
Test Type: TYPE C
Temperature: 25
Operator: Nick

Gamma Plane (°):0.0-180.0:1.0
Test Device: GPM-1800B
Distance: 9.028 m
Humidity: 60%
Inspector:

Luminous Intensity Distribution Curve(cd/klm)



C Plane (°):0.0-360.0: 30.0

Test Lab:

Test Type: TYPE C

Temperature: 25

Operator: Nick

Gamma Plane (°):0.0-180.0: 1.0

Test Device: GPM-1800B

Distance: 9.028 m

Humidity: 60%

Inspector:


Coefficients Of Utilization - Zonal Cavity Method

RC	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.5	0.5	0.5	0.3	0.3	0.3	0.1	0.1	0.1	0
RW	0.7	0.5	0.3	0.1	0.7	0.5	0.3	0.1	0.5	0.3	0.1	0.5	0.3	0.1	0.5	0.3	0.1	0
RCR	RF = 0.2																	
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	101	101	101	99
1	109	104	100	96	106	102	98	94	97	94	91	93	90	88	89	87	85	83
2	99	91	84	78	96	89	82	77	85	80	75	81	77	73	78	75	71	69
3	90	80	71	65	87	78	70	64	75	68	63	72	66	62	69	65	61	58
4	82	70	62	55	80	69	61	55	66	59	54	64	58	53	62	56	52	50
5	76	63	54	47	74	62	53	47	60	52	46	57	51	46	55	50	45	43
6	70	57	48	41	68	56	47	41	54	46	41	52	45	40	50	44	40	38
7	65	51	43	36	63	51	42	36	49	41	36	47	41	36	46	40	35	33
8	60	47	38	33	59	46	38	32	45	37	32	43	37	32	42	36	32	30
9	56	43	35	29	55	42	35	29	41	34	29	40	33	29	39	33	29	27
10	53	40	32	27	52	39	32	26	38	31	26	37	31	26	36	30	26	24

Spacing Criteria (0-180): 1.24

Spacing Criteria (90-270): 1.25

Spacing Criteria (Diagonal): 1.36



C Plane (°):0.0-360.0: 30.0

Test Lab:

Test Type: TYPE C

Temperature: 25

Operator: Nick

Gamma Plane (°):0.0-180.0: 1.0


Test Device: GPM-1800B

Distance: 9.028 m

Humidity: 60%

Inspector:

Isocandela (rectangle)



I_{max} (100%): 108 cd

(10%):	11 cd	(20%):	22 cd
(25%):	27 cd	(30%):	32 cd
(40%):	43 cd	(50%):	54 cd
(60%):	65 cd	(70%):	76 cd
(80%):	86 cd	(90%):	97 cd

C Plane (°):0.0-360.0: 30.0

Test Lab:

Test Type: TYPE C

Temperature: 25

Operator: Nick

Gamma Plane (°):0.0-180.0:1.0


Test Device: GPM-1800B

Distance: 9.028 m

Humidity: 60%

Inspector:

IsoLux Plot



Mounting Height: 5.0m Max Lux(100%): 4.3 lx

(10%): 0.4 lx	(20%): 0.9 lx
(25%): 1.1 lx	(30%): 1.3 lx
(40%): 1.7 lx	(50%): 2.2 lx
(60%): 2.6 lx	(70%): 3.0 lx
(80%): 3.5 lx	(90%): 3.9 lx

C Plane (°):0.0-360.0: 30.0

Test Lab:

Test Type: TYPE C

Temperature: 25

Operator: Nick

Gamma Plane (°):0.0-180.0:1.0

Test Device: GPM-1800B

Distance: 9.028 m



Humidity: 60%

Inspector:

Lum Limit Curve

Dazzle	Quality	Illuminance (lx)							
1.15	A	2000	1000	500	<=300				
1.50	B		2000	1000	500	<=300			
1.85	C			2000	1000	500	<=300		
2.20	D				2000	1000	500	<=300	
2.55	E					2000	1000	500	<=300

a b c d e f g h



L(cd/sq.m)	G45	G50	G55	G60	G65	G70	G75	G80	G85
C0	6024	5596	5119	4603	4027	3370	2622	1770	796
C90	8325	8142	7914	7639	7294	6816	6182	5164	2125
C180	6039	5620	5154	4636	4054	3401	2677	1849	892
C270	8118	7906	7640	7302	6892	6341	5597	4320	1023

C Plane (°):0.0-360.0: 30.0

Test Lab:

Test Type: TYPE C

Temperature: 25

Operator: Nick

Gamma Plane (°):0.0-180.0: 1.0

Test Device: GPM-1800B


Distance: 9.028 m

Humidity: 60%

Inspector:



Illuminance at a Distance



C Plane (°):0.0-360.0: 30.0

Test Lab:

Test Type: TYPE C

Temperature: 25

Operator: Nick

Gamma Plane (°):0.0-180.0:1.0


Test Device: GPM-1800B

Distance: 9.028 m

Humidity: 60%

Inspector:

Vertical IsoLux Plot



Lowest(m): 2.0m	Highest(m): 5.0m	Max Lux: 27.0 lx
(10%): 2.7 lx	(20%): 5.4 lx	
(25%): 6.7 lx	(30%): 8.1 lx	
(40%): 10.8 lx	(50%): 13.5 lx	
(60%): 16.2 lx	(70%): 18.9 lx	
(80%): 21.6 lx	(90%): 24.3 lx	

C Plane (°):0.0-360.0: 30.0

Test Lab:

Test Type: TYPE C

Temperature: 25

Operator: Nick

Gamma Plane (°):0.0-180.0:1.0

Test Device: GPM-1800B

Distance: 9.028 m

Humidity: 60%


Inspector:

Unit: 1m

Gamma Plane (°):0.0-180.0:1.0
Test Device: GPM-1800B
Distance: 9.028 m
Humidity: 60%
Inspector:



The Average Illuminance Effective Figure



UGR Table

Reflectance:										
Ceiling (cavity)	0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall	0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions	Viewed crosswise					Viewed endwise				
X=2H Y=2H	22.7	24.3	23.1	24.6	25.0	22.0	23.6	22.4	23.9	24.3
3H	24.4	25.9	24.8	26.2	26.6	23.5	25.0	23.9	25.3	25.7
4H	25.1	26.4	25.5	26.8	27.2	24.0	25.4	24.4	25.7	26.1
6H	25.5	26.8	26.0	27.2	27.6	24.3	25.6	24.7	25.9	26.4
8H	25.7	26.9	26.1	27.3	27.7	24.3	25.5	24.8	26.0	26.4
12H	25.7	26.9	26.2	27.3	27.7	24.3	25.5	24.8	25.9	26.3
X=4H Y=2H	23.1	24.5	23.6	24.9	25.3	22.6	24.0	23.0	24.3	24.7
3H	25.1	26.2	25.5	26.6	27.1	24.3	25.5	24.7	25.9	26.3
4H	25.8	26.8	26.3	27.3	27.7	24.9	25.9	25.4	26.4	26.8
6H	26.4	27.3	26.8	27.7	28.2	25.3	26.2	25.8	26.6	27.1
8H	26.5	27.4	27.0	27.8	28.3	25.4	26.2	25.8	26.7	27.1
12H	26.6	27.4	27.1	27.9	28.4	25.4	26.1	25.9	26.6	27.1
X=8H Y=4H	26.0	26.8	26.4	27.3	27.8	25.2	26.0	25.6	26.5	27.0
6H	26.6	27.3	27.1	27.8	28.3	25.6	26.3	26.1	26.8	27.3
8H	26.8	27.4	27.3	27.9	28.5	25.7	26.4	26.3	26.9	27.4
12H	26.9	27.5	27.5	28.0	28.6	25.8	26.3	26.3	26.8	27.4
X=12H Y=4H	26.0	26.7	26.5	27.2	27.7	25.2	25.9	25.7	26.4	26.9
6H	26.6	27.2	27.1	27.7	28.3	25.7	26.3	26.2	26.8	27.3
8H	26.8	27.4	27.4	27.9	28.5	25.8	26.3	26.3	26.9	27.4

Calculate in accordance with CIE 190:2010

C Plane (°):0.0-360.0: 30.0

Test Lab:

Test Type: TYPE C

Temperature: 25

Operator: Nick

Gamma Plane (°):0.0-180.0: 1.0

Test Device: GPM-1800B

Distance: 9.028 m

Humidity: 60%

Inspector:

Utilisation Factor Table(Floor cavity)

Utilisation Factors UF(F)			SHR NOM = 1.25								
Room Reflectance			Room Index(RI)								
Ceiling	Wall	Floor	0.75	1.00	1.25	1.50	2.00	2.50	3.00	4.00	5.00
0.70	0.50	0.20	0.57	0.67	0.74	0.80	0.87	0.92	0.96	1.00	1.03
	0.30		0.49	0.59	0.67	0.73	0.81	0.87	0.91	0.96	1.00
	0.20		0.43	0.54	0.61	0.67	0.76	0.82	0.86	0.93	0.97
0.50	0.50	0.20	0.55	0.65	0.72	0.77	0.84	0.89	0.92	0.96	0.99
	0.30		0.48	0.58	0.65	0.71	0.79	0.84	0.88	0.93	0.96
	0.20		0.43	0.53	0.60	0.66	0.74	0.80	0.84	0.90	0.93
0.30	0.50	0.20	0.53	0.63	0.69	0.74	0.81	0.85	0.88	0.92	0.95
	0.30		0.47	0.57	0.64	0.69	0.76	0.81	0.85	0.90	0.92
	0.20		0.42	0.52	0.60	0.65	0.73	0.78	0.82	0.87	0.90
0.00	0.00	0.00	0.40	0.50	0.57	0.62	0.69	0.74	0.78	0.82	0.85
Rating: 6W Photometrically tested without ceiling board. Multiply UF values by service correction factors Calculate in accordance with CIBSE Technical Memorandum NO.5 1980											

Utilisation Factor Table(Wall)

Utilisation Factors UF(W)			SHR NOM = 1.25									
Room Reflectance			Room Index(RI)									
Ceiling	Wall	Floor	0.75	1.00	1.25	1.50	2.00	2.50	3.00	4.00	5.00	
0.70	0.50	0.20	0.99	0.82	0.70	0.60	0.48	0.40	0.34	0.26	0.21	
	0.30		0.83	0.70	0.61	0.54	0.44	0.37	0.31	0.25	0.20	
	0.20		0.71	0.61	0.54	0.48	0.40	0.34	0.29	0.23	0.19	
0.50	0.50	0.20	0.96	0.78	0.67	0.58	0.46	0.41	0.32	0.25	0.20	
	0.30		0.81	0.68	0.59	0.52	0.42	0.35	0.30	0.24	0.19	
	0.20		0.70	0.60	0.53	0.47	0.39	0.33	0.28	0.22	0.19	
0.30	0.50	0.20	0.93	0.75	0.64	0.55	0.44	0.36	0.31	0.24	0.19	
	0.30		0.79	0.66	0.57	0.50	0.40	0.34	0.29	0.23	0.19	
	0.20		0.69	0.59	0.52	0.46	0.38	0.32	0.27	0.22	0.18	
0.00	0.00	0.00	0.59	0.49	0.42	0.37	0.30	0.25	0.21	0.17	0.14	
<p>Rating: 6W Photometrically tested without ceiling board.</p> <p>Multiply UF values by service correction factors</p> <p>Calculate in accordance with CIBSE Technical Memorandum NO.5 1980</p>												

Utilisation Factor Table(Ceiling cavity)

Utilisation Factors UF(C)			SHR NOM = 1.25									
Room Reflectance			Room Index(RI)									
Ceiling	Wall	Floor	0.75	1.00	1.25	1.50	2.00	2.50	3.00	4.00	5.00	
0.70	0.50	0.20	0.17	0.19	0.19	0.20	0.21	0.21	0.22	0.22	0.23	
	0.30		0.10	0.12	0.13	0.14	0.16	0.17	0.18	0.19	0.20	
	0.20		0.06	0.07	0.09	0.10	0.12	0.14	0.15	0.17	0.18	
0.50	0.50	0.20	0.17	0.18	0.19	0.19	0.20	0.21	0.21	0.21	0.22	
	0.30		0.10	0.12	0.13	0.14	0.16	0.17	0.17	0.19	0.19	
	0.20		0.06	0.07	0.09	0.10	0.12	0.13	0.14	0.16	0.17	
0.30	0.50	0.20	0.16	0.17	0.18	0.19	0.19	0.20	0.20	0.21	0.21	
	0.30		0.10	0.12	0.13	0.14	0.15	0.16	0.17	0.18	0.19	
	0.20		0.06	0.07	0.08	0.10	0.12	0.13	0.14	0.16	0.17	
0.00	0.00	0.00	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	
Rating: 6W Photometrically tested without ceiling board. Multiply UF values by service correction factors Calculate in accordance with CIBSE Technical Memorandum NO.5 1980												

Zonal Lumen

Gamma [°]	I _{mean} [cd]	Zonal Flux [lm]	Sum Zonal Flux [lm]	Rel Zonal Flux [%]	Sum Rel Zonal Flux [%]
0.0-1.0	107.9	0.1	0.1	0.03	0.03
1.0-2.0	107.9	0.3	0.4	0.10	0.14
2.0-3.0	107.8	0.5	0.9	0.17	0.30
3.0-4.0	107.7	0.7	1.7	0.24	0.54
4.0-5.0	107.6	0.9	2.6	0.30	0.85
5.0-6.0	107.4	1.1	3.7	0.37	1.22
6.0-7.0	107.1	1.3	5.0	0.44	1.65
7.0-8.0	106.8	1.5	6.6	0.50	2.15
8.0-9.0	106.5	1.7	8.3	0.57	2.72
9.0-10.0	106.1	1.9	10.2	0.63	3.35
10.0-11.0	105.7	2.1	12.3	0.69	4.04
11.0-12.0	105.3	2.3	14.6	0.76	4.80
12.0-13.0	104.8	2.5	17.1	0.82	5.62
13.0-14.0	104.3	2.7	19.8	0.88	6.49
14.0-15.0	103.7	2.8	22.6	0.93	7.43
15.0-16.0	103.1	3.0	25.7	0.99	8.42
16.0-17.0	102.5	3.2	28.8	1.05	9.47
17.0-18.0	101.9	3.4	32.2	1.10	10.57
18.0-19.0	101.1	3.5	35.7	1.15	11.72
19.0-20.0	100.4	3.7	39.4	1.21	12.93
20.0-21.0	99.6	3.8	43.2	1.26	14.19
21.0-22.0	98.8	4.0	47.2	1.30	15.49
22.0-23.0	97.9	4.1	51.3	1.35	16.84
23.0-24.0	97.1	4.2	55.6	1.39	18.23
24.0-25.0	96.1	4.4	59.9	1.43	19.67
25.0-26.0	95.2	4.5	64.4	1.47	21.14
26.0-27.0	94.2	4.6	69.0	1.51	22.65
27.0-28.0	93.2	4.7	73.7	1.55	24.20
28.0-29.0	92.1	4.8	78.6	1.58	25.78
29.0-30.0	91.1	4.9	83.5	1.61	27.40
30.0-31.0	90.0	5.0	88.5	1.64	29.04
31.0-32.0	88.8	5.1	93.6	1.67	30.71
32.0-33.0	87.6	5.2	98.7	1.69	32.41
33.0-34.0	86.4	5.2	104.0	1.72	34.12
34.0-35.0	85.2	5.3	109.3	1.74	35.86
35.0-36.0	84.0	5.3	114.6	1.75	37.61

C Plane (°):0.0-360.0: 30.0

Test Lab:

Test Type: TYPE C

Temperature: 25

Operator: Nick

Gamma Plane (°):0.0-180.0:1.0

Test Device: GPM-1800B

Distance: 9.028 m

Humidity: 60%

Inspector:

Zonal Lumen (Continue 1)

Gamma [°]	I _{mean} [cd]	Zonal Flux [lm]	Sum Zonal Flux [lm]	Rel Zonal Flux [%]	Sum Rel Zonal Flux [%]
36.0-37.0	82.7	5.4	120.0	1.77	39.38
37.0-38.0	81.4	5.4	125.4	1.78	41.17
38.0-39.0	80.0	5.5	130.9	1.79	42.96
39.0-40.0	78.6	5.5	136.4	1.80	44.76
40.0-41.0	77.2	5.5	141.9	1.81	46.56
41.0-42.0	75.8	5.5	147.4	1.81	48.37
42.0-43.0	74.4	5.5	152.9	1.81	50.18
43.0-44.0	72.9	5.5	158.4	1.81	51.99
44.0-45.0	71.4	5.5	163.9	1.80	53.79
45.0-46.0	69.9	5.5	169.4	1.80	55.59
46.0-47.0	68.4	5.4	174.8	1.79	57.37
47.0-48.0	66.8	5.4	180.2	1.77	59.15
48.0-49.0	65.3	5.4	185.6	1.76	60.90
49.0-50.0	63.7	5.3	190.9	1.74	62.65
50.0-51.0	62.1	5.3	196.1	1.72	64.37
51.0-52.0	60.4	5.2	201.3	1.70	66.07
52.0-53.0	58.8	5.1	206.4	1.68	67.75
53.0-54.0	57.1	5.0	211.5	1.65	69.40
54.0-55.0	55.4	4.9	216.4	1.62	71.03
55.0-56.0	53.8	4.9	221.3	1.59	72.62
56.0-57.0	52.0	4.8	226.0	1.56	74.18
57.0-58.0	50.3	4.7	230.7	1.53	75.71
58.0-59.0	48.6	4.5	235.2	1.49	77.20
59.0-60.0	46.8	4.4	239.7	1.45	78.65
60.0-61.0	45.1	4.3	244.0	1.41	80.07
61.0-62.0	43.3	4.2	248.2	1.37	81.44
62.0-63.0	41.6	4.0	252.2	1.33	82.76
63.0-64.0	39.8	3.9	256.1	1.28	84.04
64.0-65.0	38.0	3.8	259.9	1.23	85.28
65.0-66.0	36.2	3.6	263.5	1.19	86.46
66.0-67.0	34.4	3.5	266.9	1.14	87.60
67.0-68.0	32.7	3.3	270.2	1.09	88.69
68.0-69.0	30.9	3.2	273.4	1.03	89.72
69.0-70.0	29.1	3.0	276.4	0.98	90.70
70.0-71.0	27.3	2.8	279.2	0.93	91.63
71.0-72.0	25.6	2.7	281.9	0.87	92.50

C Plane (°):0.0-360.0: 30.0

Test Lab:

Test Type: TYPE C

Temperature: 25

Operator: Nick

Gamma Plane (°):0.0-180.0:1.0

Test Device: GPM-1800B

Distance: 9.028 m

Humidity: 60%

Inspector:

Zonal Lumen (Continue 2)

Gamma [°]	I _{mean} [cd]	Zonal Flux [lm]	Sum Zonal Flux [lm]	Rel Zonal Flux [%]	Sum Rel Zonal Flux [%]
72.0-73.0	23.9	2.5	284.4	0.82	93.32
73.0-74.0	22.1	2.3	286.7	0.76	94.09
74.0-75.0	20.5	2.2	288.9	0.71	94.80
75.0-76.0	18.8	2.0	290.9	0.65	95.45
76.0-77.0	17.1	1.8	292.7	0.60	96.05
77.0-78.0	15.4	1.7	294.3	0.54	96.59
78.0-79.0	13.8	1.5	295.8	0.49	97.08
79.0-80.0	12.2	1.3	297.1	0.43	97.51
80.0-81.0	10.5	1.1	298.3	0.37	97.88
81.0-82.0	8.9	1.0	299.2	0.32	98.20
82.0-83.0	7.2	0.8	300.0	0.26	98.45
83.0-84.0	5.5	0.6	300.6	0.20	98.65
84.0-85.0	4.0	0.4	301.0	0.14	98.79
85.0-86.0	2.6	0.3	301.3	0.09	98.88
86.0-87.0	1.4	0.2	301.5	0.05	98.94
87.0-88.0	0.7	0.1	301.6	0.03	98.96
88.0-89.0	0.3	0.0	301.6	0.01	98.97
89.0-90.0	0.2	0.0	301.6	0.01	98.98
90.0-91.0	0.1	0.0	301.6	0.01	98.98
91.0-92.0	0.2	0.0	301.6	0.01	98.99
92.0-93.0	0.2	0.0	301.7	0.01	99.00
93.0-94.0	0.2	0.0	301.7	0.01	99.00
94.0-95.0	0.2	0.0	301.7	0.01	99.01
95.0-96.0	0.2	0.0	301.7	0.01	99.01
96.0-97.0	0.2	0.0	301.7	0.01	99.02
97.0-98.0	0.2	0.0	301.8	0.01	99.03
98.0-99.0	0.2	0.0	301.8	0.01	99.04
99.0-100.0	0.2	0.0	301.8	0.01	99.05
100.0-101.0	0.2	0.0	301.8	0.01	99.05
101.0-102.0	0.2	0.0	301.9	0.01	99.06
102.0-103.0	0.3	0.0	301.9	0.01	99.07
103.0-104.0	0.3	0.0	301.9	0.01	99.08
104.0-105.0	0.3	0.0	302.0	0.01	99.09
105.0-106.0	0.3	0.0	302.0	0.01	99.10
106.0-107.0	0.3	0.0	302.0	0.01	99.11
107.0-108.0	0.3	0.0	302.1	0.01	99.12

C Plane (°):0.0-360.0: 30.0

Test Lab:

Test Type: TYPE C

Temperature: 25

Operator: Nick

Gamma Plane (°):0.0-180.0:1.0

Test Device: GPM-1800B

Distance: 9.028 m

Humidity: 60%

Inspector:

Zonal Lumen (Continue 3)

Gamma [°]	I _{mean} [cd]	Zonal Flux [lm]	Sum Zonal Flux [lm]	Rel Zonal Flux [%]	Sum Rel Zonal Flux [%]
108.0-109.0	0.3	0.0	302.1	0.01	99.14
109.0-110.0	0.3	0.0	302.1	0.01	99.15
110.0-111.0	0.4	0.0	302.2	0.01	99.16
111.0-112.0	0.4	0.0	302.2	0.01	99.17
112.0-113.0	0.4	0.0	302.2	0.01	99.18
113.0-114.0	0.4	0.0	302.3	0.01	99.20
114.0-115.0	0.4	0.0	302.3	0.01	99.21
115.0-116.0	0.4	0.0	302.4	0.01	99.22
116.0-117.0	0.4	0.0	302.4	0.01	99.24
117.0-118.0	0.4	0.0	302.4	0.01	99.25
118.0-119.0	0.5	0.0	302.5	0.01	99.27
119.0-120.0	0.5	0.0	302.5	0.01	99.28
120.0-121.0	0.5	0.0	302.6	0.02	99.30
121.0-122.0	0.5	0.0	302.6	0.02	99.31
122.0-123.0	0.5	0.0	302.7	0.02	99.33
123.0-124.0	0.5	0.0	302.7	0.02	99.34
124.0-125.0	0.5	0.0	302.8	0.02	99.36
125.0-126.0	0.5	0.0	302.8	0.02	99.37
126.0-127.0	0.6	0.0	302.9	0.02	99.39
127.0-128.0	0.6	0.0	302.9	0.02	99.41
128.0-129.0	0.6	0.0	303.0	0.02	99.42
129.0-130.0	0.6	0.1	303.0	0.02	99.44
130.0-131.0	0.6	0.1	303.1	0.02	99.46
131.0-132.0	0.6	0.1	303.1	0.02	99.47
132.0-133.0	0.6	0.1	303.2	0.02	99.49
133.0-134.0	0.6	0.1	303.2	0.02	99.51
134.0-135.0	0.6	0.1	303.3	0.02	99.52
135.0-136.0	0.7	0.1	303.3	0.02	99.54
136.0-137.0	0.7	0.1	303.4	0.02	99.56
137.0-138.0	0.7	0.1	303.4	0.02	99.57
138.0-139.0	0.7	0.0	303.5	0.02	99.59
139.0-140.0	0.7	0.0	303.5	0.02	99.61
140.0-141.0	0.7	0.0	303.6	0.02	99.62
141.0-142.0	0.7	0.0	303.6	0.02	99.64
142.0-143.0	0.7	0.0	303.7	0.02	99.65
143.0-144.0	0.7	0.0	303.7	0.02	99.67

C Plane (°):0.0-360.0: 30.0

Test Lab:

Test Type: TYPE C

Temperature: 25

Operator: Nick

Gamma Plane (°):0.0-180.0:1.0

Test Device: GPM-1800B

Distance: 9.028 m

Humidity: 60%

Inspector:

Zonal Lumen (Continue 4)

Gamma [°]	I _{mean} [cd]	Zonal Flux [lm]	Sum Zonal Flux [lm]	Rel Zonal Flux [%]	Sum Rel Zonal Flux [%]
144.0-145.0	0.8	0.0	303.8	0.02	99.69
145.0-146.0	0.8	0.0	303.8	0.02	99.70
146.0-147.0	0.8	0.0	303.9	0.02	99.72
147.0-148.0	0.8	0.0	303.9	0.01	99.73
148.0-149.0	0.8	0.0	303.9	0.01	99.75
149.0-150.0	0.8	0.0	304.0	0.01	99.76
150.0-151.0	0.8	0.0	304.0	0.01	99.77
151.0-152.0	0.8	0.0	304.1	0.01	99.79
152.0-153.0	0.8	0.0	304.1	0.01	99.80
153.0-154.0	0.8	0.0	304.2	0.01	99.81
154.0-155.0	0.8	0.0	304.2	0.01	99.83
155.0-156.0	0.8	0.0	304.2	0.01	99.84
156.0-157.0	0.9	0.0	304.3	0.01	99.85
157.0-158.0	0.9	0.0	304.3	0.01	99.86
158.0-159.0	0.9	0.0	304.3	0.01	99.88
159.0-160.0	0.9	0.0	304.4	0.01	99.89
160.0-161.0	0.9	0.0	304.4	0.01	99.90
161.0-162.0	0.9	0.0	304.4	0.01	99.91
162.0-163.0	0.9	0.0	304.5	0.01	99.92
163.0-164.0	0.9	0.0	304.5	0.01	99.93
164.0-165.0	0.9	0.0	304.5	0.01	99.93
165.0-166.0	0.9	0.0	304.5	0.01	99.94
166.0-167.0	0.9	0.0	304.6	0.01	99.95
167.0-168.0	0.9	0.0	304.6	0.01	99.96
168.0-169.0	0.9	0.0	304.6	0.01	99.96
169.0-170.0	0.9	0.0	304.6	0.01	99.97
170.0-171.0	0.9	0.0	304.6	0.01	99.98
171.0-172.0	0.9	0.0	304.7	0.01	99.98
172.0-173.0	0.9	0.0	304.7	0.00	99.99
173.0-174.0	0.9	0.0	304.7	0.00	99.99
174.0-175.0	1.0	0.0	304.7	0.00	99.99
175.0-176.0	0.9	0.0	304.7	0.00	100.00
176.0-177.0	1.0	0.0	304.7	0.00	100.00
177.0-178.0	0.9	0.0	304.7	0.00	100.00
178.0-179.0	0.9	0.0	304.7	0.00	100.00
179.0-180.0	1.0	0.0	304.7	0.00	100.00

C Plane (°):0.0-360.0: 30.0

Test Lab:

Test Type: TYPE C

Temperature: 25

Operator: Nick

Gamma Plane (°):0.0-180.0:1.0

Test Device: GPM-1800B

Distance: 9.028 m

Humidity: 60%

Inspector: